

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231881
Address: 2129 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, March 21, 2024

Corrective Action Required:

2	Miscellaneous Correction	2129 SW Rutherford. Occupancy (2) Basement bottom stair to header does not have the allowable 6'8" headroom clearance Exterior of house is not ready for inspection
---	--------------------------	---

Comments: