

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Friday, March 22, 2024

Informational:

1	Misc	—Portal frame inspection only— Passed
---	------	---------------------------------------

Corrective Action Required:

2	Miscellaneous Correction	3832 SW Ravengate. All rough LIB in bathroom 2 needs nails Roof boots are missing Lateral support truss above kitchen to stairwell Nail primary bedroom corner to code IBeams in basement not properly supported at wall pockets One air supply line needs to be supported 10 feet on center
---	--------------------------	--

This all rough is for the main house only.
Exterior patio with roof will be inspected for all rough at a later date

Comments: