

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233629
Address: 3215 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, March 22, 2024

Corrective Action Required:

2	Misc	- (2) king studs each side of front door opening - plans call for (7) studs each end of beam in garage - anchor all steel columns in basement - columns to be of correct size. See plans - secure conduit within 12" of service panel - outlet required for stairwell wall space
---	------	---

Comments: