

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20231450

Address: 410 NW CHIPMAN RD, LEES SUMMIT, MO 64086 400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	John Jackson	Partial	Friday, March 22, 2024

Informational:

1 Misc

All pervious reports where placed on PRCOM20231450 JMJ  
Erosion control is still maintaining, but appears need regular maintenance to ensure it stays securely in the ground.

**Comments:**