

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240893
Address: 4805 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, March 25, 2024

Corrective Action Required:

1	Misc	-Fb wall space from soffit space at wet bar location ; fb bathroom sink wall; fb closet wall from joist space -Protect plumbing at wet bar sink -Complete vent bathroom fan to outdoor -Shim gap underneath joists at joist hangers above bathroom **OK TO INSULATE
---	------	---

Comments: