

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Tuesday, March 26, 2024

Informational:

1 Misc —Portal frame inspection only— Passed

Corrective Action Required:

3 Miscellaneous
Correction -Patio plans calls for a double 2x8 ridge beam to be installed
-rafter to siding along south side needs to be installed to tie into the existing structure

House all rough is completed and passed

Comments: