



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113619, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, August 23, 2011

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT: ALL WALLS EXCEPT EAST EXTERIOR AND WET WALL BETWEEN RESTROOMS

Corrective Action Required

2 MISC

IPC 305.8: INSTALL HARDENED STEEL SHIELD PLATES AT STUDS AND T&B PLATES WHEREVER SURFACE OF PIPE IS LESS THAN 1-1/2" FROM FACE OF FRAMING. SHIELD PLATES SHALL COVER THE AREA OF THE PIPE WHERE THE MEMBER IS NOTCHED OR BORED AND SHALL EXTEND A MINIMUM OF 2" ABOVE SOLE PLATES & BELOW TOP PLATES. CHECK ALL.

Comments: