CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20234789Address:519 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Robb Popp	Failed	Tuesday, March 26, 2024
Corrective Action Required:			
1 Misc	 Provide code compliant handrail at both sides of upper stairs All stairs to be max 7" in rise and not vary more than 3/8" Openings at risers to be no more than 4" Return all handrails per code Existing handrail at top stairs is required to be 34"-38" aff, extend 12" and return per code 		

Comments: