

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240550

Address: 3734 SW KNOXVILLE CT, LEES SUMMIT, MO 640823736 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Kyle Beard	Passed	Tuesday, March 26, 2024

Comments: