

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232356

Address: 457 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081459 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081461 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081463 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081465 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081467 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081455 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Alex Fischer	Failed	Tuesday, March 26, 2024

Corrective Action Required:

1 Misc

Rated assembly inspection:

- 467 bathroom 3rd floor north wall insufficient screws
- 465 PASSED
- 463 northwest corner 8ft up garage wall insufficient screws
- 461 PASSED
- 459 PASSED
- 457 PASSED
- 455 PASSED

Comments: