

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240196  
Address: 1712 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Kyle Beard	Failed	Wednesday, March 27, 2024

Corrective Action Required:

3	Miscellaneous Correction	-Some silt fence has been damaged or is missing and gravel pile in the driveway needs to be spread. -Full erosion control must be installed and maintained until CofO -No further inspections until full compliance of erosion control
---	--------------------------	--

**Comments:**