

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240426
Address: 2122 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Residential	Robb Popp	Failed	Wednesday, March 27, 2024

Corrective Action Required:

1	Misc	-Close open space at electrical panel -Install bonding bushings and jumpers at disconnect
---	------	--

Comments: