

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233918  
Address: 2234 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Wednesday, March 27, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>-Complete final grade, sod, splash blocks, foundation drainage</li><li>-Garage entry door must self close and latch</li><li>-Seal penetration near garage entry door</li><li>-Loose receptacle left of range</li><li>-Missing handrail at top flight of basement stairs</li><li>-Complete receptacles at wet bar</li><li>-Secure LFMC at water heater</li><li>-Install security screws at entry doors</li><li>-Label non GFCI receptacle at sump pump</li><li>-Install missing insulation at rim joist in mechanical near vent</li><li>-AC to have max 50 amp breaker</li><li>-Install ladder in window well greater than 44" in height</li></ul>
---	------	---

**Comments:**