

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082  
2116 SW HOLDBROOKS DR, LEES SUMMIT,  
MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Wednesday, March 27, 2024

Corrective Action Required:

1	Miscellaneous Correction	2118 SW Holdbrooks. (East side) Rated assembly  -Fire rated plywood deck can not have more than 1/4 inch gap Rated assembly wall in bedroom 1 at south wall ends before reaching the corner  2116 (west side)  -Fire rated plywood is chipping and needs replaced or repaired -Caulk gaps where needed at plywood
---	--------------------------	---

**Comments:**