

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215800
Address: 1600 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|---------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Failed | Wednesday, March 27, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Clean storm inlets pay all fees obtain issued lawn irrigation permit -provide 3rd party inspection report for suspended slab -provide engineering for retaining wall -update plot plan to show as built -address sump pump discharge -provide spark rings for kitchen outlets properly installed -secure conduit within 12" of water heater |
|---|------|---|

Comments: