

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20223975  
Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Kyle Beard	Partial	Wednesday, March 27, 2024

Informational:

1	Miscellaneous Correction	Underground electrical from power pole to the structures west southwest corner passed. This is a partial pass only. Okay to cover.
---	-----------------------------	--

Informational:

2	Miscellaneous Correction	Underground electrical from main disconnect to panels passed. Ok to cover  Underground electrical from panels to trash compactor passed. Ok to cover
---	-----------------------------	--

This is a partial pass only

Corrective Action Required:

3	Miscellaneous Correction	Underground electrical to outside light post south, west and north sides and trash compactor passed. Ok to cover
---	-----------------------------	--

East side has been run under ground but not to the piers. Do not cover until inspected

This is a partial pass only

**Comments:**