

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241062  
Address: 3513 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Kyle Beard	Passed	Thursday, March 28, 2024

Informational:

2	Miscellaneous Correction	Footing inspection passed by a third party. Piers were not mentioned in the footing report.
---	-----------------------------	---

**Comments:**