

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236605
Address: 3832 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Friday, March 29, 2024

Informational:

1	Misc	—Portal frame inspection only— Passed
---	------	---------------------------------------

Corrective Action Required:

3	Miscellaneous Correction	Patio plans calls for a double 2x8 ridge beam to be installed.
---	--------------------------	--

Double ridge beam is still not installed and or a design professional letter is not uploaded for design change
03/29/24 KBEARD.
Not ready for inspection

Comments: