

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222783
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Partial	Friday, March 29, 2024

Partial Correction:

1	Misc	-Sanitary line between lines M and N complete to exterior -Sanitary line between lines Y and Z complete to exterior -Sanitary line between lines A and B from lines 3 to 5 complete to exterior **Install cleanouts at exterior of building
---	------	--

Comments: