CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20235952Address:1932 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------------|------------|----------|------------------------|
| All Rough Inspection - Residential | Kyle Beard | Failed | Friday, March 29, 2024 |

Corrective Action Required:

2 Miscellaneous Correction -Top of new vertical Fire blocking in basement is not completed (has large holes) - Have engineers letter address the garage top plate where the breaks in plates are on top of each other

Comments: