

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Monday, April 01, 2024

Informational:

1	Misc	-Building 1, Segment A, 1st through 4th Floor for first layer of rated assembly behind all tubs approved
---	------	--

Corrective Action Required:

2	FIRST FLOOR
---	-------------

Corrective Action Required:

3	SECOND FLOOR
---	--------------

Corrective Action Required:

4	THIRD FLOOR
---	-------------

Corrective Action Required:

5	FOURTH FLOOR
---	--------------

\*BUILDING A:

\*\*THROUGHOUT:

-Decks not ready for inspection

-OK FOR RC EXCEPT AS NOTED

400

-Dryer duct over spanned

412

-Have engineer provide correction for broken truss in bedroom

-Dryer duct over spanned

**Comments:**