

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240903  
Address: 1924 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                         | Inspector: | Outcome: | Date:                  |
|-------------------------------------|------------|----------|------------------------|
| <b>Water Service Inspection - R</b> | Kyle Beard | Partial  | Monday, April 01, 2024 |

Informational:

|   |                             |  |
|---|-----------------------------|--|
| 1 | Miscellaneous<br>Correction | PEX is ran to about 20 feet out from the foundation.Okay to cover<br><br>This is a partial pass only |
|---|-----------------------------|--|

**Comments:**