CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231252

Address: 2126 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Erosion Control Kyle Beard Failed Monday, April 01, 2024

Corrective Action Required:

1 DCM2 ESC DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS

DEFICIENT UNTIL ADEQUATE EROSION CONTROL PROVIDED.

INSTALLATION

- REPAIR SILT FENCE AT FRONT OF LOT.

Corrective Action Required:

2 Miscellaneous Repair silt fence at the front of the lot and reinstall silt fence along the east

Correction side of the property

Comments: