

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233614

Address: 2136 SW OSAGE DR, LEES SUMMIT, MO 640822134 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Monday, April 01, 2024

Informational:

1	Miscellaneous Correction	Erosion control measures are in place at the time of all rough. Full erosion control must be maintained until CofO
---	--------------------------	--

Informational:

2	Miscellaneous Correction	Full erosion control is in place and must be maintained until CofO
---	--------------------------	--

Corrective Action Required:

3	Miscellaneous Correction	Both units needs silt fence installed at the front of the property by the street and unit 2134's east side. Full erosion control must be maintained until CofO
---	--------------------------	--

Comments: