

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Tuesday, April 02, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Gas pressure gauge at 2116 (west side) is missing -Gas pressure gauge on first inspection read 0 PSI All rough can not pass until gas inspection passes 04/02/24. KBEARD
---	--------------------------	--

Comments: