

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|---------------------------|
| Rated Assembly Inspection | Robb Popp | Failed | Wednesday, April 03, 2024 |

Corrective Action Required:

| | | |
|---|-------------|---|
| 1 | FIRST FLOOR | -Shaft layer at 2nd floor in AHU 1E-233 **First layer at 233-install screws as specified in UL details |
|---|-------------|---|

Comments: