

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232880
Address: 1523 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, April 03, 2024

Corrective Action Required:

2	Misc	-sod -splash blocks and sump pump discharge -provide as graded plot plan -will check water meter at time of sod, meter to be 14"-18" from top of meter to well lid ring -(2) 1/2" through bolts at deck post to beam connections -spark rings at basement wet bar backsplash outlets -
---	------	--

Comments: