


200, 208, and 216 NW Executive Way




Google

200, 208, and 216 NW Executive Way.

Earth below electrical equipment in this photo is being excavated.

This existing metering / service equip. Will be lowered and reused. Conduits will extend up to this location and service entrance wires will be spliced in a junction box.




lighting contactor box.

Leave this panel housing and use as j box / replace if required. Extend conduits from new panel below.

Remove and replace with junction box

TX pad
couple feet
west of drive



DISCLAIMER AND COPYRIGHT NOTICE
The information contained on this drawing is used to locate, identify and/or inventory Evergy Inc. electrical facilities located on parcels of land in the Evergy Inc. service area. It is intended for reference purposes only and is NOT to be considered or used as a legal description. Map information is believed to be accurate but accuracy is not guaranteed. This information should not be relied upon as a substitute for an actual field survey. This drawing is not to be used as a substitute for using the ONE-CALL system for purposes of digging and excavation. You must call ONE-CALL (811) to notify operators of underground facilities of proposed excavation or digging to request that member companies mark their underground facilities before they dig to no extent will Evergy Inc. be liable for any damages, including loss of data, lost profits, business interruption, loss of business information or other pecuniary loss that might arise from the inaccurate use or misuse of this map or the information it contains. You are prohibited from reproducing or distributing this drawing or any portion of it without written permission of Evergy Inc. © Evergy Inc. All rights reserved.

EXISTING
INSTALL
REMOVE
MODIFY



CONTACTS

PROJECT DESIGNER: PHILLIP
PHONE #: (816) 347-4339
CUSTOMER: PHONE #:

TITLE Relocate 3 phase UG transformer
ADDRESS 200 NW EXECUTIVE WAY
CITY STATE
12 KV DATE 2/29/2024

WO# M106067088
CENTER LEES SUMMIT
CIRCUIT 0263012051
DESIGNED BY PAI6389

SHEET 1 OF 1

REV.	DATE	BY	CHECKED	APPROVED
------	------	----	---------	----------



Think Safety!

DWG FILE # M106067088-1