

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235933
Address: 1059 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, April 03, 2024

Corrective Action Required:

2	Misc	- provide posts for front porch - Land bracing for gable at front entry - Finish plumbing for master soaking tub - Secure SEC cable within 12" of entry kitchen - Fb floor penetration gas line fire place
---	------	--

Comments: