



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113089, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Failed	Thursday, August 25, 2011

Corrective Action Required

1 MISC

SPACING OF ROOFTOP PIPING SUPPORT BLOCKS: ADD ONE NEAR EACH OF TWO 90's

Corrective Action Required

2 MISC

IFGC 404.8: EXPOSED METALLIC PIPING MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.

**Gas Service
Inspection -
Commercial**

John Borns	Not Ready	Thursday, August 25, 2011
------------	-----------	---------------------------

Corrective Action Required

1 MISC

LSCO 7-608: GAS PIPING PRESSURE TEST BELOW LEE'S SUMMIT 10 PSI REQUIRED MINIMUM

Corrective Action Required

2 MISC

ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED HANG ADDRESS-STAMPED MEDALLIONS ON LOAD SIDE PIPES

Comments: