
Work Order Title: Chipman and Cedar Creek (5 Day 2/20/24)

Work Order: 31110430 Project #:806562 Municipality: Lees Summit



## Existing Main / Asset Material Valves/Meters/Regulators/CP **Main and Service Fittings** Excess Flow Valve End Cap Line Stopper Proposed Bare Steel Flange Saddle/Weldolet Meter --- Abandon Screwed Steel Reducer Controllable Tee Controllable Valve Proposed Previous WO Cast Iron Tee Elbow Regulator Plastic Abandon Previous WO Coupling Anode ➡ Transition






- 1. INSTALL AND ABANDON STEEL AND PLASTIC MAIN AND SERVICES PER SPIRE OPM STANDARDS. 2. SEE STD. 200.0 FOR PRESSURE TESTING PIPING REQUIREMENTS
- 3. SEE STD. 180.B FOR EFV AND/OR MANUAL SHUTOFF VALVE INSTALLATION REQUIREMENTS
- 4. SEE STD. 170.I AND 190.G FOR TRACE WIRE AND TEST STATION INSTALLATION INFORMATION.
  5. CORROSION PROTECTION INSPECTOR TO CHECK CATHODIC PROTECTION OF ALL EXISTING
- CATHODICALLY PROTECTED FACILITIES EXPOSED AND PROTECTED FACILITIES EXPOSED AND DIRECT STEPS NECESSARY TO MAINTAIN PROPER ISOLATION AND CATHODIC PROTECTION AS REQUIRED. A PIPE OBSERVATION REPORT IS TO BE CREATED IN MAXIMO ON READINGS
- 6. INSTALL ANODES PER STD. 190.C AND/OR TEST STATIONS PER STD. 190.G PER INSTRUCTIONS FROM CORROSION PROTECTION INSPECTOR.
- 7. CONDUCT INITIAL CATHODIC PROTECTION SURVEY FOR NEW STEEL INSTALLATION. (SEE 190.I FOR CATHODIC PROTECTION AT TIE INS)
- 8. CREATE PIPE OBSERVATIONS IN MAXIMO TO DOCUMENT EXPOSED PIPE CONDITIONS PER STD. 190.A, EXTERNAL CORROSION.
  9. FOR UTILITY LOCATES, CALL ONE-CALL SYSTEM
- "811" OR (1-800-344-7483), AND ALL OTHER AFFECTED UTILITIES 10. CONTACT GIS DEPARTMENT FOR NECESSARY FIELD NOTES AT 314-349-2963.

  11. CONTACT ROW TO SECURE NECESSARY
- EASEMENTS AND FOR ANY SURVEY WORK @ (314-658-5497 OR 314-349-2933)
- 12. SEE STD. 170.J FOR SQUEÉZE-OFF PROCEDURE 13. SEE STD. 170.A FOR GAS INTERRUPTION PROCEDURE REQUIREMENTS. CONTACT SYSTEM CONTROL AT 314-658-5486 OR 314-658-5488 PRIOR TO ANY WORK
- 14. SEE STD. 150.A AND 150.E FOR RADIOGRAPHIC EXAMINATION REQUIREMENTS
- 15. SPIRE PERSONNEL SHOULD FOLLOW STANDARD PRECAUTIONS REGARDING THE POTENTIAL FOR DRIP OIL TO BE PRESENT IN ACTIVE GAS MAINS AND ADHERE TO APPROVED PROCEDURES FOR MANAGEMENT/DISPOSAL OF ANY PIECES OF PIPE GENERATED IN THE COURSE OF ABANDONMENT. ANY DOCUMENTED DRIPS SHOULD BE CLEARED AND DRAINED BEFORE ABANDONMENT.

## Check for Work Order Authorization

DESIGNER: 40448	REVISION DATE(S):
DATE:	



Work Order Title: Chipman and Cedar Creek
Work Order: 31110430 Project #:806562

**Municipality: Lees Summit** 

1:600

1 inch = 50 feet





Tie-in Number Soap Test  Yes  No Date: Time: System Gauge Pressure: Signature:	Tie-in Number Soap Test  Yes  No Date: Time: System Gauge Pressure:	Tie-in Number Soap Test  Yes  No Date: Time: System Gauge Pressure:	Tie-in Number Soap Test  Yes  No Date: Time: System Gauge Pressure:	Tie-in Number Soap Test  Yes  No Date: Time: System Gauge Pressure: Signature:	PRESSURE TEST OF GAS MAINS (One Test Per Sheet)
522		Creek Ln	Partie SS	720	Pipe Size: Length (ft):  Pipe Size: Length (ft):  Pipe Size: Length (ft):  Design MAOP  Test Medium: Water \ Air \ Gas Other:  Gauge Type: Recording Indicating Dead Weight  Gauge I.D.:  Calibration Date:  Test Date:  Start Time: End Time:
2" Plastic 55		The same			Start Press.: End Press.:  Start Temp.*: End Temp.*:  * Water or Pipe temperature, not ambient  If Discharge volume is over 1,000 gallons -
2" Plastic T		701			Contact Lab for sample.  Note all leaks or failures, including cause, and corrective action taken in comments below.  SEE STD. 200.0 FOR PRESSURE TESTING OF MAIN REQUIREMENTS. FOR ANY QUESTIONS REGARDING THE STANDARD, PLEASE CONTACT PIPELINE SAFETY AND COMPLIANCE AT 314-349-0537 OR 816-266-3033.  Conducted By:
Comments:					Signature: Date:  Printed Name: