



WATER UTILITIES LEE'S SUMMIT

1200 SE Hamblen Road | Lee's Summit, MO 64081

P: 816.969.1900 | F: 816.969.1935

backflow@cityofls.net | LSwater.net

Backflow Prevention Assembly Test Data & Maintenance Report

Customer Crash Champions			
Service Address 451 SE Oldham Pkwy.			
Location of Backflow Assembly on Property Next to water meter			
Date of Test 3/25/24	Time 11 : 43 AM <input checked="" type="checkbox"/> PM <input type="checkbox"/>	Supply Pressure _____ LBS	Air Gap (2 x Supply Diameter) Supply: _____ IN. Gap: _____ IN. <input checked="" type="checkbox"/> PASS <input type="checkbox"/> FAIL
Type of Assembly <input checked="" type="checkbox"/> DC <input type="checkbox"/> DCDA (Detector) <input type="checkbox"/> PVB* (See Bottom of Form)	<input type="checkbox"/> RP <input type="checkbox"/> RPDA (Detector)	Manufacturer Febco	Model 850
Size 3/4"	Serial Number HF76968		
Height off Floor _____ FT _____ IN	Protection From Freezing: <input type="checkbox"/> Yes <input type="checkbox"/> No Flooding: <input type="checkbox"/> Yes <input type="checkbox"/> No	Supply Source <input type="checkbox"/> Public Potable Water <input type="checkbox"/> Both <input type="checkbox"/> Non-Potable Water (e.g., LAKE)	New Installation <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Initial Test		Final Test After Repair	
Reduced Pressure Principle Assembly:		Reduced Pressure Principle Assembly:	
RELIEF VALVE opened at _____ PSID (2 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	RELIEF VALVE opened at _____ PSID (2 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
2nd CHECK held backpressure	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	2nd CHECK held backpressure	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
1st CHECK held in direction of flow _____ PSID (5 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	1st CHECK held in direction of flow _____ PSID (5 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
Note: Failure of any of the above items, requires repair.		Note: Failure of any of the above items, requires repair.	
Initial Test		Final Test After Repair	
Double Check Valve Assembly:		Double Check Valve Assembly:	
1st CHECK held in direction of flow <u>2.5</u> PSID (1 PSID or more)	<input type="checkbox"/> Passed <input checked="" type="checkbox"/> Failed	1st CHECK held in direction of flow _____ PSID (1 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
2nd CHECK held backpressure	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	2nd CHECK held backpressure	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
2nd CHECK held in direction of flow <u>2.0</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	2nd CHECK held in direction of flow _____ PSID (1 PSID or more)	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/> Passed <input type="checkbox"/> Failed
Note: Failure of any of the above items, requires repair.		Note: Failure of any of the above items, requires repair.	
Application:		Comments	
<input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Fire Line <input type="checkbox"/> Fire Line By-Pass **Meter # _____ **Meter Read _____ <input type="checkbox"/> Point of Use			
The Above Report is Certified to be True, Accurate and Complete			
Tested By (Print) Auxilio Angeles		Repaired by (Print) (Signature) _____	
Company Curby's Lawn & Garden, LLC		Final Test By (Print) (Signature) _____	
Missouri Certification Number 33-12585		Owner or Owner's Representative W. Curby Hughes	
Expiration Date 3/31/2027		Date 3/25/24	
<p>*If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations. New PVB installations or replacements are not permitted.</p> <p>**METER # and METER READ for the fire line by-pass meter on detector assemblies are required.</p> <p>Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.</p>			