

## **DEVELOPMENT SERVICES**

## **Residential Plan Review**

April 05, 2024

JWM CONTRACTING LLC 420 NE BROCKTON DR LEES SUMMIT, MO 64064 (913) 530-4205 JWM CONTRACTING LLC 420 NE BROCKTON DR LEES SUMMIT, MO 64064 (913) 530-4205

Permit No: PRRES20241491

Plan Name:

Project Address: 4005 NE APPLE GROVE DR, LEES SUMMIT, MO 64064

Parcel Number: 308587

Location:

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - ENG ROOF AND FLOOR SYSTEM ( DEFERRED ) UNFINISHED BASEMENT - UNCOVERED

**DECK** 

## **Revisions Required**

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Brandon Kalwei Rejected

- 1. Deck location, with dimensions to property lines must be provided on the plot plan. Label as uncovered deck
- 2. The top of foundation elevation must be provided on the plot plan.
- 3. The Basement floor elevation and basement type (e.g. full/standard, daylight, walk-out, etc.)

Residential Plan Review Reviewed By: Brandon Kalwei Rejected

1. One (1) complete permit application. Please put the company name and not your personal name as the applicant and the deck sq. ft.

**Reviewed By:** 

Pending

## The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:							
Residential, garage Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		651 2786 1725					
				Roofing Material		Number of Bathrooms	4.5
Number of Bedrooms	4	Number of Stories	2				
Number of Living Units	1	Total Living Area	2786				