

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240962
Address: 1925 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Monday, April 08, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Silt fence between this property and 1921 SW MERRYMAN Ned's to be repaired or replaced - gravel needs to be spread from the street to the foundation
---	-----------------------------	---

Comments: