

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240626
Address: 3212 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, April 08, 2024

Corrective Action Required:

1	Misc	All plumbing under slab to be properly supported(not done)
---	------	---

Comments: