

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233055  
Address: 3258 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Monday, April 08, 2024

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none"><li>- post address of contrasting colors</li><li>- Sidewalk inspection pending</li><li>- Final grading and sod</li><li>- Splash blocks required</li><li>- Label non gfci outlet in garage and basement</li><li>- Provide anti siphon device to spigot by water main shut off</li><li>- Seal top of electrical meter an A/C disconnect</li><li>- Seal all exterior penetrations</li><li>- Anchor garage door rails within 18" of bottom</li><li>- Address steel column wrong size called out at all rough</li></ul> |
|---|------|--|

**Comments:**