

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241108
Address: 2520 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed - Stop Work	Monday, April 08, 2024

Corrective Action Required
1 Misc

REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION
CONTROL INSTALLATION.

PROVIDE EROSION CONTROL ALONG THE STREET AND ALONG
REAR SIDE OF THE LOT

Comments: