

Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 7

DATE: April 08, 2024 PROJECT NO: 230117

RE: Streets of West Pryor – Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 7 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-7 are marked with a Delta 8, Rev #8, or similar.

Architectural Items:

- A-1 Sheet G-001 Code plan updated to show 2 hr rated separation wall.
- A-2 Sheet A-101 Partition type 'P1' 2hr rated partition updated to call out and match structural 2x6 stud framing.

Sheet S-102 - Structural Wood Shearwall Schedule indicates the minimum structural Construction, while, the as-built structure has been erected with more than the minimum structural requirements using 2 layers of 5/8" Gyp on both sides to meet the UL rating of U301. The addition of the second 2 hr wall dividing Suites A & B will be built to match UL U301.


Supplementary data attached is UL U301 pdf document with assembly requirements of 2x6 wood stud.

DESIGN NO. UL U301

FIRE RATING: 2 HOURS STC RATING: 40 SOUND TEST: USG-161206 SYSTEM THICKNESS: 8" [203 MM]

INTERIOR LOCATION:

FRAMING TYPE: WOOD STUD (LOAD-BEARING)




ASSEMBLY REQUIREMENTS:

GYPSUM PANELS: TWO LAYERS 5/8" [15.9 MM] SHEETROCK® ECOSMART GYPSUM PANEL (UL TYPE ULIX™)

WOOD STUDS: 2" X 6" [38 X 140 MM] WOOD STUDS, 16" [406 MM] O.C.

5-1/2" [140 MM] FIBERGLASS INSULATION INSULATION:

GYPSUM PANELS: TWO LAYERS 5/8" [15.9 MM] SHEETROCK® ECOSMART GYPSUM PANEL (UL TYPE ULIX™)



GENERAL WALL NOTES:

- REFER TO APPLICABLE CODES REQUIREMENTS TO ENSURE COMPLIANCE PRIOR TO CONSTRUCTION.
- FOR THE MOST UP-TO-DATE DETAILS, INCLUDING CONSTRUCTION VARIATIONS, REFER TO THE PUBLISHED DESIGN.
- 3. WHERE DESIGN NO. INDICATES "PER", THE FIRE RATING IS BASED ON LABORATORY TEST DATA OF THE REFERENCED SIMILARLY CONSTRUCTED ASSEMBLIES.
- STUD SIZES AND INSULATION THICKNESS ARE MINIMUM UNLESS OTHERWISE STATED IN THE PUBLISHED ASSEMBLY.
- 5. STUD AND FASTENER SPACINGS ARE MAXIMUM UNLESS OTHERWISE STATED IN THE PUBLISHED ASSEMBLY.
- 6. PANEL ORIENTATION SHALL BE AS SPECIFIED IN THE PUBLISHED DESIGN.
- FIRE-RATINGS ARE FROM BOTH SIDES UNLESS OTHERWISE STATED.
- 8. FIRE-RATINGS ARE MAINTAINED WITH ONE OR MORE OF THE FOLLOWING MODIFICATIONS: INCREASE STUD DEPTH, INCREASE STUD MATERIAL THICKNESS, DECREASE STUD SPACING, DECREASE FASTENER SPACING, INCREASE INSULATION THICKNESS UP TO CAVITY DEPTH.
- WHERE ACOUSTICAL PERFORMANCE IS PROVIDED IN AN ESTIMATED RANGE, THE VALUES ARE BASED ON LABORATORY TEST DATA OF SIMILARLY CONSTRUCTED ASSEMBLIES.
- SOUND-RATINGS ARE MAINTAINED WITH ONE OR MORE OF THE FOLLOWING MODIFICATIONS: INCREASE STUD DEPTH, DECREASE STUD MATERIAL THICKNESS, INCREASE STUD SPACING, INCREASE FASTENER SPACING, INCREASE INSULATION THICKNESS UP TO CAVITY DEPTH. MODIFICATIONS MUST NOT EXCEED LIMITATIONS OF FIRE RATING.





Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 6

DATE: March 13, 2024 PROJECT NO: 230117

RE: Streets of West Pryor - Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 6 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-6 are marked with a Delta 7, Rev #7, or similar.

MEP Items:

MEP-1 Sheet E-101 – Electrical Riser Diagram updated to two-hundred amp system.

MEP-2 Sheet E-201 – Double-Section Panelboard Schedule updated for two-hundred amp system.



Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 5

DATE: February 19, 2024 PROJECT NO: 230117

RE: Streets of West Pryor – Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 5 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-5 are marked with a Delta 6, Rev #6, or similar.

Architectural Items:

- A-1 Sheet G-001 Code summary updated with usable square foot occupant load calculations and exit requirements for tenant suites A, B & C.
 - A-1.1 Sheet G-001 Code plan updated with occupant load calculations and egress width for tenant suites A, B & C.
- A-2 Sheet A-101 Two hour rated demising wall added to full East to West length of the building spaced 21 feet from face of gypsum board to the other second two hour rated demising wall. Creating and dividing the Core & Shell building into now three separate tenant suites.
 - A-1.A Updating tenant suite designations as Suite A, B & C respectively.
 - A-1.B Updating tenant suite square footage.
- A-3 Sheet A-102 Roof Top Unit added to service enlarged Tenant Suite B space.

MEP Items:

MEP-1 Sheet M-101 – Restroom removed; RTU added to service enlarged Tenant Suite B space.

MEP-1.A Water heater and Plumbing Fixture schedules removed.

MEP-2 Sheet M-201 – Restroom removed; RTU added to service enlarged Tenant Suite B space.

MEP-2.A Roof Top Unit Schedule updated with added RTU.

MEP-2.B Exhaust Fan schedule removed.

MEP-3 Sheet E-101 – Restroom removed; RTU added to service enlarged Tenant Suite B space.

MEP-3.A Panelboard schedule updated.

MEP-3.B Electrical riser diagram updated with 400A panels.

MEP-3.C Electrical Floor Plan – Power updated for tenant suites A & B.

MEP-4 Sheet E-201 – Floor Plan – Lighting updated to three tenant suites A,B & C respectively and Double-Section Panelboard Schedule added to sheet.



Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 4

DATE: November 07, 2023 **PROJECT NO: 230117**

RE: Streets of West Pryor - Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 4 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-4 are marked with a Delta 5, Rev #5, or similar.

Architectural Items:

- A-1 Sheet G-001 Drawing A3-Code Plan changed from 3 tenant building to 2 tenant building.
 - A-1.A Drawing A3-Code Plan updated egress load tags.
- A-2 Sheet A-101 Floor changed from 3 tenant building to 2 tenant building. Including removal of fire demising wall, restroom and mechanical room.
 - A-2.A Room tags updated to illustrate proper Suite nomenclature and square footage.
- A-3 Sheet A-201 Drawing C1-East Elevation update illustrating change to Stone wainscot and EIFS 1 at previous brake metal pilaster.
 - A-3.A Drawing C1-East Elevation changed from 3 tenant building to 2 tenant building and tenant signage updated on elevation.
- A-4 Sheet A-401 Removed from scope.



Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 3

DATE: June 20, 2023 PROJECT NO: 230117

RE: Streets of West Pryor - Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 3 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-3 are marked with a Delta 4, Rev #4, or similar.

Architectural Items:

A-1 Sheet A-101 – Updated location of future pass-through openings on Suite C's South demising wall.

Structural Items:

S-1 Sheet S-102 - Updated location of future pass-through openings on Suite C's South demising wall.



Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 2

DATE: July 07, 2023 PROJECT NO: 230117

RE: Streets of West Pryor - Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 2 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.

DESCRIPTION:

Clarification Items:

G-1 Attached drawings associated with ASI-2 are marked with a Delta 3, Rev #3, or similar.

Architectural Items:

- A-1 Sheet A-101 Future pass-through openings added on East and West ends of Suite C's South Demising wall.
 - A-1.A Key plan note #2 for Future pass-through added to Keyed Plan Notes legend.
- A-2 Sheet A-102 RTUs rotated 90 degrees for structural support purposes.
- A-3 Sheet A-201 Door C101 update to be 7' and Tempered Glass.
 - A-3.A Reference to MEP exterior utilities indicated on West Elevation Drawing A1.
- A-4 Sheet A-601 Door schedule updated to represent C101 door as 7' and Tempered Glass.

Structural Items:

- S-1 Sheet S-001 Updates to general notes Risk Category and Wind Load information.
- S-2 Sheet S-101 Foundation updates to columns B.1-3 & B.9-3 and dimensional spacing on East.
 - S-2.A Addition of West pilaster foundation.
- S-3 Sheet S-102 Future pass-through openings added to shearwall
 - S-3.A Wood shearwall schedule updated.
 - S-3.B Addition of West wall pilaster.
- S-4 Sheet S-103 RTUs rotated 90 degrees for structural support.
 - S-4.A Future pass through openings located in shearwall.
 - S-4.B Addition of West wall pilaster.
- S-5 Sheet S-201 Updated shearwall pass-through openings and west wall pislater added to isometric.
- S-6 Sheet S-301 Bolt type and dimensional location update to Baseplate Details drawings BP-2.

MEP Items:

- MEP-1 Sheet ME-201 Updates to Light Fixture Schedule to show "C" fixtures on exterior. MEP-1.A Movement of Light Poles.
- MEP-2 Sheet ME-202 Updated placement of exterior utilities
- MEP-3 Sheet M-101 Swapping the respective placement of RTU 3 and RTU 4 for each other. MEP-3.A Rotation of RTU units
- MEP-4 Sheet M-201 Rotation of RTU units
- MEP-5 Sheet E-101 Swapping the respective placement of RTU 3 and RTU 4 for each other.

 MEP-5.A Updated information on respective Panelboard Schedule for RTU 3 and RTU 4.

 MEP-5.B Rotation of RTU units
- MEP-5.C Exterior Utilities shifted south past West wall Pilaster
- MEP-6 Sheet E-201 Mounted exterior lighting updated to "C" fixtures' on floor plan.



Architecture Interiors

Planning

Topeka, Kansas Oklahoma City, Oklahoma

ARCHITECT'S SUPPLEMENTAL INSTRUCTION NO. 1

DATE: June 20, 2023 PROJECT NO: 230117

RE: Streets of West Pryor – Lot 5 Core & Shell

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. If changes in Contract Sum or Contract Time are required, Contractor shall submit Change Order Request in a timely manner.

ASI No. 1 is part of the contract Bid and Construction Documents and shall govern in the performance of the Work.


DESCRIPTION:

Clarification Items:

- G-1 Attached drawings associated with ASI-1 are marked with a Delta 2, Rev #2, or similar.
- G-2 Title blocks of all Architectural drawings have been updated with exact site address.
- G-3 Sheets G-001, A-101, & A-301 Room Labels have changed to Suite A, B, & C.

Architectural Items:

- A-1 Sheet A-101 UL Fire rated wall assembly information has been added to partition type P1.
 - A-1.A Partition types P2 & P3 have been added to partition type legend.
 - A-1.B Partition types P2 & P3 have been tagged in plan.
- A-2 Sheet A-102 Pilaster added to West wall.
- A-3 Sheet A-301 Wall construction updated to clarify horizontal lap aluminum siding.



schwerdt design grou

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115




MO CERTIFICATE OF AUTH, #F003538


11-07-2023


0

02-19-2024 04-08-2024

COVER SHEET










TRASH ENCLOSURE GATE ELEVATION

SCALE: 1/4" = 1'-0"










TRASH ENCLOSURE WALL SECTION

SCALE: 1/2" = 1'-0"

schwerdt design group architecture | interiors | planning

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



MO CERTIFICATE OF AUTH. #F00353876

5

BUILDIN F WES SHE

> SUBMISSION DATES PROGRESS PRINT ONLY


ORE

SUMMIT

SITE PLAN

230117

A-100



architecture | interiors | planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115




MO CERTIFICATE OF AUTH. #F00353876

06-13-2023 07-07-2023 07-26-2023 11-07-2023


FIRST FLOOR PLAN

02-19-2024



architecture | interiors | planning


2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



MO CERTIFICATE OF AUTH, #F00353876

06-13-2023 07-07-2023 ASI-2 ASI-5 02-19-2024

ROOF PLAN



schwerdt design grou

2231 sw wanamaker rd topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



SCHWERDT DESIGN GROUP INC

MO CERTIFICATE OF AUTH. #F00353876

CORE & SHELL BUILDING

STREETS OF WEST PRYOR LOT 5
2070 NW LOWENSTEIN DR, LEES SUMMIT, JACKSON COUNTY, MISSOURI

SUBMISSION DATES
PROGRESS PRINT ONLY
ADD-1 06-02-2023
ASI-2 07-07-2023


11-07-2023

SHEET TITLE EXTERIOR ELEVATIONS


PROJECT NUMBER **230117**

ASI-4

SHEET NUMBER
A-201



schwerdt design grour architecture | interiors | plannin 2231 sw wanamaker rd suite 30 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



MO CERTIFICATE OF AUTH. #F0035387


DR \mathbf{m} **LOWENST** ORE

SUBMISSION DATES PROGRESS PRINT ONLY 06-13-2023 ASI-1

WALL SECTIONS

230117

A-301






schwerdt design group architecture | interiors | planning

2231 sw wanamaker rd topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



SCHWERDT DESIGN GROUP INC

MO CERTIFICATE OF AUTH. #F00353876

0T 5

REETS OF WEST PRYOR LOT !


SUBMISSION DATES
PROGRESS PRINT ONLY


ORE


SHEET TITLE
WALL SECTIONS

PROJECT NUMBER 230117

A-302







A4) SECTION @ WEST WALL
SCALE: 1/2" = 1'-0"

A-303

SUMMIT ORE

ULDIN WES

 $\mathbf{\Omega}$

里

OUNTY,

SON

schwerdt design grou

architecture | interiors | plannin

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

MICHAEL K HAMPTON

IO CERTIFICATE OF AUTH. #F0035387


5

#MO# A-2008027042

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115

SUBMISSION DATES PROGRESS PRINT ONLY


WALL SECTIONS





schwerdt design group

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



MO CERTIFICATE OF AUTH. #F00353876

5


OURI SUMMIT

SUBMISSION DATES PROGRESS PRINT ONLY

WALL SECTIONS

230117

A-304



schwerdt design group

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115




MO CERTIFICATE OF AUTH. #F00353876

CKSON WES WES R, LEES SU $\mathbf{\Omega}$ **NW LOWENST**

2070 SUBMISSION DATES PROGRESS PRINT ONLY 11-07-2023

ENLARGED RESTROOM PLAN



schwerdt design grour

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115




MO CERTIFICATE OF AUTH. #F0035387

5 ULDIN WES OUNTY $\mathbf{\Omega}$ 里

SUBMISSION DATES PROGRESS PRINT ONLY

SUMMIT

BUILDING DETAILS



architecture | interiors | planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



MO CERTIFICATE OF AUTH. #F00353876


5

BUILDIN F WES

SUBMISSION DATES

SUMMIT

BUILDING DETAILS



schwerdt design group

architecture | interiors | planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115

MICHAEL K HAMPTON

#MO# A-2008027042

MO CERTIFICATE OF AUTH, #F00353876

KSON

ASI-2 07-07-2023

SUBMISSION DATES

DOOR / FRAME SCHEDULE & DETAILS

230117

A-601

VERIFY ALL DIMENSIONS SHOWN WITH ARCHITECTURAL DRAWINGS AND EXISTING CONDITIONS PRIOR TO CONSTRUCTION. DISCREPANCIES SHALL BE RESOLVED BEFORE PROCEEDING WITH CONSTRUCTION. CONTRACTOR SHALL COORDINATE THE WORK OF ALL TRADES AND MAKE NECESSARY INVESTIGATIONS AND FIELD MEASUREMENTS. INFORM ENGINEER OF ALL DISCREPANCIES.

THE CONTRACTOR SHALL VERIFY THE SIZE AND LOCATIONS OF PENETRATIONS AND EMBEDDED ITEMS THROUGH THE STRUCTURE FOR ALL TRADES. PENETRATIONS SHALL BE SUBJECT TO APPROVAL BY THE ARCHITECT AND STRUCTURAL ENGINEER.

SEE MECHANICAL, ELECTRICAL, ARCHITECTURAL DRAWINGS FOR ANCHORS, PIPE SLEEVES, CONDUITS OR OTHER ITEMS TO BE EMBEDDED IN OR PASS THROUGH CONCRETE. IN GENERAL, EMBEDMENTS AND PENETRATIONS LESS THAN 12 INCHES IN DIAMETER ARE NOT SHOWN ON THE STRUCTURAL DRAWINGS.

SEE ARCHITECTURAL DRAWINGS FOR DOOR HEIGHTS AND WALL OPENING DIMENSIONS.

STRUCTURAL ELEMENTS ARE NON-SELF SUPPORTING AND REQUIRE INTERACTION WITH OTHER ELEMENTS FOR STABILITY. FRAMING AND WALLS SHALL BE TEMPORARILY BRACED BY THE CONTRACTOR UNTIL PERMANENT BRACING, FLOOR AND ROOF DECKS AND WALLS HAVE BEEN INSTALLED AND CONNECTIONS BETWEEN THESE ELEMENTS HAVE BEEN MADE.

SUPPORT OF ALL NON-STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. NON-STRUCTURAL ELEMENTS ARE THOSE THAT DO NOT CONTRIBUTE TO THE DIRECT LOAD PATH OF BOTH THE GRAVITY AND LATERAL FORCE RESISTING SYSTEMS. THESE ELEMENTS INCLUDE, BUT ARE NOT LIMITED TO PARTITIONS, FINISHES, MILLWORK, MECHANICAL EQUIPMENT, DUCTWORK, PIPING, LIGHT FIXTURES, ELECTRICAL CONDUIT, STORAGE RACKS, ETC. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ENSURING THAT THESE ELEMENTS ARE ADEQUATELY CONNECTED TO THE STRUCTURE TO RESIST ALL APPLIED LOADS. NOTIFY THE STRUCTURAL ENGINEER OF RECORD IF UNUSUAL SUPPORT CONDITIONS EXIST.

WORK REQUIRING SPECIAL INSPECTIONS SHALL BE INSPECTED ACCORDING TO THE BUILDING CODE AND INCLUDES: CONCRETE, REINFORCING STEEL, STRUCTURAL WELDING, HIGH-STRENGTH BOLTING, AND MASONRY. RE: SPECIAL INSPECTION PROGRAM TABLE WHEN APPLICABLE.

DESIGN CRITERIA:

BUILDING CODE: 2018 INTERNATIONAL BUILDING CODE AS ADOPTED AND AMENDED BY THE CITY OF LEE'S SUMMIT, MISSOURI.

ROOF: 20 PSF

SNOW LOADS: GROUND SNOW LOAD, Pg: 20 PSF FLAT-ROOF SNOW LOAD, Pf: 20 PSF SNOW EXPOSURE FACTOR, Ce: 1.0 SNOW LOAD IMPORTANCE FACTOR, Is: 1.0

THERMAL FACTOR, Ct: 1.0 BASIC WIND SPEED: 115 MPH EXPOSURE CATEGORY: C

BASIC INTERNAL PRESSURE COEFFICIENT, GCpi: ±0.18 BASIC COMPONENTS AND CLADDING PRESSURE (ADJUSTED TO COMPLY WITH BUILDING CODE): ±20 PSF @ INTERIOR ZONES

±25 PSF @ END ZONES

SEISMIC IMPORTANCE FACTOR, le: 1.0 SPECTRAL RESPONSE ACCELERATIONS:

Ss: 0.1274 S1: 0.0612

SPECTRAL RESPONSE COEFFICIENTS: Sds: 0.102 Sd1: 0.069

SITE CLASS: C

SEISMIC DESIGN CATEGORY: B BASIC SEISMIC-FORCE-RESISTING SYSTEM: LIGHT-FRAMED WALLS WITH WOOD STRUCTURAL PANELS & STEEL ORDINARY MOMENT FRAMES

DESIGN BASE SHEAR: Cs x W SEISMIC RESPONSE COEFFICIENTS, Cs: 0.0157 & 0.0291 RESPONSE MODIFICATION FACTOR, R: 6.5 & 3.5 ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE

FOUNDATION AND EARTHWORK NOTES:

REFER TO THE GEOTECHNICAL EXPLORATION AND FOUNDATION RECOMMENDATIONS: WEST PRYOR VILLAGE, LEE'S SUMMIT, MISSOURI / COOK, FLATT, & STROBEL ENGINEERS PA, KASNAS CITY, KANSAS (CFS NO 19-5125) / JUNE 15, 2018

THE FOUNDATION BEARING MATERIAL SHALL BE INSPECTED AND APPROVED BY A GEOTECHNICAL ENGINEER BEFORE FOUNDATIONS ARE CONSTRUCTED.

AT STEPPED FOOTINGS, THE LOWER FOOTING SHALL BE PLACED FIRST.

FOUNDATIONS HAVE BEEN DESIGNED FOR A NET ALLOWABLE SOIL BEARING PRESSURE OF 2,500 PSF FOR CONTINUOUS FOOTINGS AND 3,000 PSF FOR ISOLATED SPREAD FOOTINGS. FOUNDATIONS SHALL BEAR DIRECTLY ON A 24-INCH THICK, GEOGRID REINFORCED AGGREGATE PAD (GRAP) DESIGNED AND CONSTRUCTED AS OUTLINED IN THE GEOTECHNICAL REPORT, SECTION 7.2.

WALL FOUNDATION SHALL BEAR AT MINIMUM OF 3'-0" BELOW ADJACENT FINISH GRADE, UNLESS OTHERWISE NOTED.

UNUSUAL CONDITIONS OR CHANGES TO THE FOUNDATIONS AS REQUIRED BY FIELD CONDITIONS SHALL BE REFERRED TO THE ENGINEER FOR APPROVAL.

REFER TO GEOTECHNICAL REPORT FOR SUBGRADE PREP REQUIREMENTS FOR SLAB-ON-GRADE CONSTRUCTION. PREPARED SUBGRADES EXCAVATED TO INSTALL UTILITIES BELOW FLOOR SLABS SHALL BE BACKFILLED AND COMPACTED AS SPECIFIED BY THE GEOTECHNICAL ENGINEER.

REFER TO GEOTECHNICAL REPORT FOR COMPACTION REQUIREMENTS.

MAINTAIN ALL EXCAVATIONS FREE OF WATER.

CONCRETE NOTES:

CONCRETE SHALL HAVE THE FOLLOWING UNLESS OTHERWISE SPECIFIED (SELECT PROPORTIONS FOR CONCRETE IN ACCORDANCE WITH ACI 318):

	MAX WATER/ CEMENT RATIO	MINIMUM COMPRESSIVE STRENGTH AT 28 DAYS
INTERIOR SLAB ON GRADE	0.45	3,000 PSI
FOOTINGS	0.45	4,500 PSI
FOUNDATION WALLS	0.45	4,500 PSI
GRADE BEAMS	0.45	4,500 PSI
DRILLED PIERS	0.50	4,000 PSI
CONCRETE ON STEEL DECK	0.45	3,000 PSI

REINFORCING STEEL SHALL BE BILLET STEEL CONFORMING TO ASTM A615, GRADE 60.

WELDED WIRE FABRIC SHALL CONFORM TO ASTM A185.

CEMENT SHALL CONFORM TO ASTM C150, TYPE I OR II.

AGGREGATES SHALL CONFORM TO ASTM C33. COARSE AGGREGATE SHALL CONSIST OF 1" MAXIMUM AGGREGATE SIZE. COMBINED GRADATION SHALL HAVE A UNIFORM **DISTRIBUTION AS FOLLOWS:**

5-20% RETAINED ON 3/4", 1/2", 3/8", NO. 4, NO. 8, NO. 16, NO. 30 AND NO. 50 SIEVES; LESS THAN 5% PASSING NO. 50 SIEVE.

MATERIALS AND ADMIXTURES SHALL NOT CONTAIN CALCIUM CHLORIDE.

ALL EXTERIOR AND CONCRETE EXPOSED TO FREEZE/THAW CYCLES SHALL BE AIR-ENTRAINED 6%(±) BY VOLUME. THIS INCLUDES BUT IS NOT LIMITED TO FOOTINGS, FOUNDATION WALLS AND GRADE BEAMS.

SLEEVES, OPENINGS, OR OTHER ATTACHMENTS NOT SHOWN ON DRAWINGS SHALL BE APPROVED BY THE ENGINEER PRIOR TO PLACING CONCRETE.

MINIMUM TENSION LAP SPLICE LENGTHS AND TENSION DEVELOPMENT LENGTHS SHALL BE AS SCHEDULED, UNLESS NOTED OTHERWISE ON THE DRAWINGS. WELDED WIRE FABRIC SHALL LAP ONE (1) FULL SQUARE PLUS TWO (2) INCHES.

MAINTAIN CONCRETE COVER AS SCHEDULED.

REINFORCING STEEL FABRICATION AND INSTALLATION SHALL BE IN ACCORDANCE WITH THE LATEST EDITION OF THE CRSI MANUAL OF STANDARD PRACTICE.

ALL REINFORCING AND EMBEDDED ANCHOR BOLTS SHALL BE ACCURATELY PLACED AND TIED PRIOR TO POURING CONCRETE. "STABBING" OF DOWELS OR ANCHOR BOLTS IS NOT ALLOWED.

CONSTRUCTION JOINTS IN WALLS AND ELEVATED FORMED SLABS SHALL BE KEYED (1 1/2" DEEP BY 1/3 MEMBER AREA) AND REINFORCING SHALL CONTINUE THROUGH JOINT OR BE TENSION LAP SPLICED. CONSTRUCTION JOINTS SHALL BE LOCATED BY THE CONTRACTOR TO LEAST IMPAIR THE STRUCTURE. JOINT LOCATIONS SHALL BE APPROVED BY THE ENGINEER.

EMBEDDED CONDUIT SHALL NOT BE LARGER IN OUTSIDE DIMENSION THAN 1/3 THE OVERALL THICKNESS OF SLAB, WALL OR BEAM IN WHICH THEY ARE EMBEDDED. THEY SHALL NOT BE SPACED CLOSER THAN 3 DIAMETERS OR WIDTHS ON CENTER.

CONDUIT LOCATED WITH CONCRETE SECTIONS SHALL COMPLY WITH ACI 318 REQUIREMENTS.

INTERIOR FLOOR SLABS SHALL COMPLY WITH ACI 117, SHALL MEET THE REQUIREMENTS OF A TYPE 5, SINGLE COURSE, HARD STEEL-TROWELED FINISH AS DESCRIBED IN AC1 302, AND SHALL ACHIEVE AN OVERALL FF25/FL20 TOLERANCE.

ADHESIVE ANCHORS IN CONCRETE OR FULLY GROUTED MASONRY SHALL BE ITW RAMSET/REDHEAD EPCON CERAMIC 6 SYSTEM, HILTI HY200, OR SIMPSON AT-XP. ADHESIVE ANCHORS FOR HOLLOW BLOCK AND OTHER MASONRY SHALL BE HILTI HY270 OR SIMPSON SET-XP.

STRUCTURAL STEEL ENCASED WITHIN CONCRETE SHALL COMPLY WITH AISC TOLERANCES.

CONSTRUCT MASONRY IN ACCORDANCE WITH THE IBC. MASONRY REQUIRES LEVEL 1 QUALITY ASSURANCE (RE: SPECS). ALL MASONRY SHALL BE LAID IN RUNNING (COMMON) BOND USING THE LOW-LIFT METHOD OF GROUTING. REFER ARCHITECTURAL PLAN FOR ALL BLOCK COURSING.

MASONRY DESIGN IS BASED ON A MINIMUM COMPRESSIVE STRENGTH (F'm) OF ASSEMBLY OF 1,500 PSI.

MASONRY UNITS SHALL MEET THE REQUIREMENTS OF ASTM C-90, GRADE N, WITH A NET AREA COMPRESSIVE STRENGTH OF 1,900 PSI.

MORTAR AT ALL MASONRY BELOW GRADE AND TYPE S AT ALL OTHER MASONRY. GROUT SHALL BE PREPARED IN ACCORDANCE WITH ASTM C-476, WITH A MINIMUM

MORTAR SHALL BE PREPARED IN ACCORDANCE WITH ASTM C-270. PROVIDE TYPE M

COMPRESSIVE STRENGTH OF 2,000 PSI AT 28 DAYS.

LAP SPLICE BAR REINFORCEMENT FOR MASONRY PER LAP SCHEDULE AND JOINT REINFORCEMENT A MINIMUM OF 6 INCHES.

REINFORCING STEEL SHALL BE BILLET STEEL CONFORMING TO ASTM A615, GRADE 60.

CONCRETE MASONRY UNITS BELOW GRADE SHALL BE SOLID GROUTED.

CELLS WITH REINFORCING SHALL BE SOLID GROUTED AND VIBRATED.

STRUCTURAL STEEL NOTES:

MASONRY NOTES:

STRUCTURAL STEEL SHALL CONFORM TO THE FOLLOWING, UNLESS OTHERWISE

WIDE FLANGE SHAPES (W, WT): ASTM A992 (Fy=50 KSI) OTHER ROLLED SHAPES (M, S, HP, C, L): ASTM A36 (Fy=36 KSI) STEEL PIPE: ASTM A53, GRADE B (Fy=35 KSI) SQUARE AND RECTANGULAR TUBE: ASTM A500, GRADE B (Fy=46 KSI) ANCHOR BOLTS: ASTM F1554, GRADE 36 HEADED ANCHOR STUDS: ASTM A108, GRADES 1010 TO 1020 PLATES AND BARS: ASTM A36 (Fy=36 KSI)

SHEAR CONNECTORS AND HEADED WELDED STUDS OF TYPE AND SIZE NOTED SHALL

STRUCTURAL STEEL SHALL BE FABRICATED AND ERECTED IN ACCORDANCE WITH GOOD STANDARD PRACTICE AND IS THE RESPONSIBILITY OF THE CONTRACTOR.

PROPER FIT IN THE FIELD OF STRUCTURAL STEEL SHALL BE IN ACCORDANCE WITH GOOD STANDARD PRACTICE AND IS THE RESPONSIBILITY OF THE CONTRACTOR.

THE FABRICATOR SHALL BE RESPONSIBLE FOR THE DESIGN AND PERFORMANCE OF ALL CONNECTIONS NOT FULLY DESIGNED OR DETAILED ON THE CONTRACT DOCUMENTS.

ANCHOR BOLTS SHALL BE ASTM F1554, A36 UNO. ANCHOR BOLTS SHALL BE SET WITH TEMPLATES WITH THE APPROPRIATE BOLT PROJECTION, 4" MINIMUM UNO. PROVIDE DOUBLE NUTS AND DOUBLE WASHERS FOR STEEL COLUMN ANCHOR BOLTS TO ALLOW FOR ADJUSTMENT IN BASE PLATE ELEVATION.

NON-SHRINK GROUT UNDER BASE PLATES SHALL BE NON-METALLIC WITH A MINIMUM COMPRESSIVE STRENGTH OF 5,000 PSI AT 28 DAYS.

HIGH STRENGTH BOLTED CONNECTIONS SHALL CONFORM TO THE AISC SPECIFICATIONS FOR STRUCTURAL JOINTS USING A325 BOLTS. UNLESS OTHERWISE NOTED, HIGH STRENGTH BOLTS MAY BE TIGHTENED BY ANY METHOD THEREIN. REGARDLESS OF THE METHOD USED IN TIGHTENING, A HARDENED WASHER SHALL BE USED UNDER THE TURNED ELEMENT. UNLESS OTHERWISE NOTED, BOLTED CONNECTIONS SHALL BE MADE WITH 3/4"Ø, ASTM A325 HIGH STRENGTH BOLTS.

CONNECTIONS REQUIRING FULL PRETENSIONING ARE SLIP-CRITICAL, AND INCLUDE BOLTED COLUMN SPLICES AND CONNECTIONS SUBJECT TO DIRECT TENSION.

ALL WELDING SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION OF THE STRUCTURAL WELDING CODE, AWS D1.1. UNLESS NOTED OTHERWISE, MINIMUM WELD SIZE SHALL BE PER AISC 360, BUT SHALL BE NO LESS THAN 3/16" FILLET.

FIELD WELDING SHALL NOT BE STARTED UNTIL JOINT ELEMENTS ARE BOLTED IN INTIMATE CONTACT AND/OR ADJUSTED TO DIMENSIONS INDICATED WITH ALLOWANCE FOR EXPECTED WELD SHRINKAGE. MAINTAIN PLUMBNESS AND TRUENESS OF THE

FIELD WELDS FOR STRUCTURAL STEEL SHALL BE MADE WITH LOW HYDROGEN ELECTRODES. WELD FILLER METAL SHALL HAVE A MINIMUM TENSILE STRENGTH OF 70

WOOD NOTES:

GENERAL STRUCTURAL WOOD FRAMING SHALL MEET THE MINIMUM STRESS REQUIREMENTS FOR DOUGLAS-FIR #2 AND SHALL BEAR THE STAMP OF AN APPROVED TESTING AGENCY.

ROOF SHEATHING SHALL BE 5/8" (19/32" MIN) PLYWOOD WITH A SPAN RATING OF AT LEAST 32/16. PANELS SHALL BE NAILED WITH 10d NAILS AT 6" O.C. AT PANEL EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. 1/8" GAP BETWEEN INDIVIDUAL SHEETS. PLYWOOD SHALL BE APA RATED C-D EXTERIOR AND SHALL BEAR THE STAMP OF AN APPROVED TESTING AGENCY.

ALL WOOD-TO-WOOD CONNECTIONS SHALL MEET THE MINIMUM NAILING REQUIREMENTS OF THE BUILDING CODE.

PROVIDE SIMPSON CONNECTION HARDWARE AS SHOWN ON THE DRAWINGS. SUBSTITUTIONS MUST BE APPROVED BY THE ARCHITECT AND STRUCTURAL ENGINEER PRIOR TO USE. INSTALL CONNECTION HARDWARE ACCORDING TO THE MANUFACTURER'S SPECIFICATIONS.

WALL SHEATHING SHALL BE 1/2" OSB ON THE EXTERIOR FACE OF ALL EXTERIOR WALLS. PANELS SHALL BE NAILED WITH 10d GALVANIZED NAILS AT 4" O.C. AT PANEL EDGES AND 12" O.C. AT INTERMEDIATE SUPPORTS. ALL PANEL EDGES SHALL BE BLOCKED.

INSTALL ALL ROOF PLYWOOD SHEATHING WITH THE LONG DIMENSION OF THE PANEL PERPENDICULAR TO THE SUPPORTS WITH A MINIMUM OF TWO SPANS FOR EACH PANEL. STAGGER ALL END JOINTS. PROVIDE 1/8" SPACE AT PANEL JOINTS FOR **EXPANSION PER APA.**

PREFABRICATED WOOD TRUSS NOTES:

SPECIAL INSPECTIONS OF THE FABRICATION PROCESS OF PRE-FABRICATED WOOD STRUCTURAL ELEMENTS AND ASSEMBLIES SHALL BE IN ACCORDANCE WITH THE IBC.

TRUSSES SHALL BE CONFIGURED TO FOLLOW FINAL ROOF LINES, UNLESS NOTED

TRUSSES SHALL BE DESIGNED FOR ALL LOAD COMBINATIONS REQUIRED BY THE BUILDING CODE. IN NO CASE SHALL THE DEAD LOAD BE LESS THAN 15 PSF ON THE TOP CHORD AND 10 PSF ON THE BOTTOM CHORD.

TRUSS MANUFACTURER SHALL SUPPLY ALL TRUSS CONNECTIONS USING PREFABRICATED STEEL CONNECTORS AS REQUIRED.

CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL TEMPORARY AND PERMANENT BRACING IN ADDITION TO ANY BRACING INDICATED ON THE PLANS.

BE DESIGNED BY AND STAMPED BY A PROFESSIONAL ENGINEER PROVIDED BY CONTRACTOR AND/OR TRUSS MANUFACTURER. APPLIED ROOF SHEATHING AND OTHER ROOFING MATERIALS SHALL NOT BE ASSUMED TO PROVIDE SUFFICIENT BRACING FOR TRUSS CHORDS.

PLATE CONNECTED WOOD TRUSSES BY THE TRUSS PLATE INSTITUTE. PROVIDE PERMANENT AND TEMPORARY BRACING ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.

SPLICE & DEVELOPMENT LENGTHS FOR REINFORCEMENT (UNLESS NOTED OTHERWISE ON THE DRAWINGS)

 $f_V = 60,000 \text{ psi}$ f'c = 3,000 psi

BAR SIZE	LENGTH OF LA FOR REINFO (INC		LENGTH O DEVELOPM	HOOK LENGTH	BAR SIZE		
	TOP BARS*	OTHERS	HOOKED BARS				
3	28	22	22	17	9	6	3
4	38	29	29	22	11	8	4
5	47	36	36	28	14	10	5
6	56	43	43	33	17	12	6
7	81	63	63	48	20	14	7
8	93	72	72	55	22	16	8
9	105	81	81	62	25	20	9
10	118	91	91	70	28	22	10
11	131	101	101	78	31	24	11
14			121	93	38	31	14
18			161	124	50	41	18

*TOP BARS ARE HORIZONTAL BARS SO PLACED THAT MORE THAN 12" OF CONCRETE IS CAST IN THE MEMBER BELOW THE BAR. HORIZONTAL BARS IN WALLS ARE TO BE CONSIDERED AS TOP BARS. VERTICAL BARS MAY BE CONSIDERED AS OTHER BARS.

UNLESS EITHER OF THE FOLLOWING TWO CASES EXIST FOR STRAIGHT BARS, THE DEVELOPMENT OR SPLICE LENGTH FOR STRAIGHT BARS IN THE ABOVE TABLE MUST BE MULTIPLIED BY 1.5:

I. THE CLEAR SPACING OF BARS BEING DEVELOPED OR SPLICED IS GREATER THAN OR EQUAL TO ONE BAR DIAMETER, THE CLEAR COVER IS GREATER THAN OR EQUAL TO ONE BAR DIAMETER, AND STIRRUPS OR TIES PROVIDED THROUGHOUT THE DEVELOPMENT OR SPLICE LENGTH MEET OR EXCEED THE CODE MINIMUM.

II.THE CLEAR SPACING OF BARS BEING DEVELOPED OR SPLICED IS GREATER THAN OR EQUAL TO TWO BAR DIAMETERS AND THE CLEAR COVER IS GREATER THAN OR EQUAL TO ONE BAR DIAMETER.

THE DEVELOPMENT LENGTH FOR HOOKED BARS, SIZE 11 AND SMALLER, PLACED WITH SIDE COVER GREATER THAN OR EQUAL TO 2 1/2" AND COVER ON THE BAR EXTENSION BEYOND THE HOOD (90° HOOK ONLY) GREATER THAN OR EQUAL TO 2", MAY BE MULTIPLIED BY 0.7.

VALUES IN THE ABOVE TABLE ARE NOT TO BE USED FOR EPOXY COATED REINFORCING AND/OR REINFORCING PLACED IN CONCRETE CONTAINING LIGHTWEIGHT AGGREGATE.

CONCRETE COVER FOR REINFORCEMENT

(UNLESS NOTED OTHERWISE ON THE L	JRAWINGS)
LOCATION	MINIMUM COVER
CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH	3"
CONCRETE EXPOSED TO EARTH OR WEATHER: #6 AND LARGER #5 AND SMALLER	2" 1 1/2"
CONCRETE NOT EXPOSED TO WEATHER OR IN CONTACT WITH THE GROUND: SLABS, WALLS, AND JOISTS: #14 AND LARGER #11 AND SMALLER BEAMS AND COLUMNS	1 1/2" 3/4" 1 1/2"

500 north broadway oklahoma city, ok 7310 phone: 405.231.3105 fax: 405.231.3115



S

9

SUBMISSION DATES 2023-05-23 ASI #2 07/07/2023

CERTUS STRUCTURAL ENGINEER

> 900 S. Kansas Avenue; Suite 400 Topeka, Kansas 66612 Phone: (785) 291-0400 Fax: (785) 291-0401 Proj #:01190008.120 **Certificate Of Authorization**

> > **Revit 2023 Local**


230117

ALL TEMPORARY AND PERMANENT BRACING FOR INDIVIDUAL TRUSS MEMBERS SHALL

SHOP FABRICATED WOOD TRUSSES SHALL MEET DESIGN SPECIFICATIONS FOR METAL

COORDINATE ALL TRUSS DETAILS WITH ARCHITECTURAL PLANS

GENERAL NOTES



5

COLUMN SCHEDULE						
MARK	SIZE					
C-1	HSS4x4x1/4					
C-2	HSS5X5X1/4					
C-3	DBL HSS9X7X3/8					
C-4	(7) 2X8					

CERTUS =

STRUCTURAL ENGINEER 900 S. Kansas Avenue; Suite 400 Topeka, Kansas 66612 Phone: (785) 291-0400 Fax: (785) 291-0401 Proj #:01190008.120 **Certificate Of Authorization**

> E-1392 Revit 2023 Local

230117

2023-05-23

FOUNDATION PLAN

ASI #2 07/07/2023

COORDINATE ALL PENETRATIONS THROUGH THE SLAB AND ALL UNDER SLAB ITEMS WITH OTHER TRADES BEFORE CONSTRUCTION.


C-(#) - DENOTES COLUMN MARK, REFERENCE SCHEDULE

F-(#) - DENOTES FOOTING MARK, REFERENCE SCHEDULE

BP-(#) - DENOTES COLUMN BASE PLATE TYPE, REFERENCE DETAILS

VERIFY ALL DIMENSIONS SHOWN WITH ARCHITECTURAL AND EXISTING CONDITIONS PRIOR TO CONSTRUCTION. INFORM ENGINEER OF ALL DISCREPANCIES.

C-4





ULDIN OF SOURI

5


2023-05-23 ASI #2 07/07/2023

ASI #3 07/26/2023

WALL FRAMING PLAN

230117

Revit 2023 Local



NOTE: FACE OF STUD ALIGNS WITH THE CONCRETE SLAB EDGE FOR ALL EXTERIOR WALLS. ALL PLAN DIMENSIONS TO EXTERIOR WALLS ARE TO FACE OF STUD/FACE OF CONCRETE SLAB. ALL DIMENSIONS TO INTERIOR WALLS ARE TO FACE OF STUD/STRUCTURAL WALL.

ROOF FRAMING PLAN

SCALE: 1/8" = 1'-0"

ROOF CONSTRUCTION: WOOD SHEATHING (19/32" MIN) OVER PREFAB WOOD ROOF TRUSSES @ 2'-0" OC MAX. SHEATHING SHALL BE CONTINUOUS UNDER AREAS OF OVERBUILD. REFERENCE GENERAL NOTES FOR SHEATHING SPECIFICATIONS AND ATTACHMENT.

DESIGN ALL TRUSSES FOR 15 PSF NET UPLIFT.

PROVIDE BRIDGING AS PRESCRIBED BY THE TRUSS MANUFACTURER REQUIREMENTS.

TOS - TOP OF STEEL ELEVATION: NOTED THUS (ELEV)

TOP OF PARAPET = 125-0 (MAX)

TRUSS BEARING ELEVATION = 114-4


TYPICAL HEADERS IN OPENINGS LESS THAN 4'-0" SHALL BE (4) 2X8 OR DEEPER, ALL HEADERS IN OPENINGS UP TO 6'-6" SHALL BE (4) 2X10 OR DEEPER, ALL HEADERS IN OPENINGS UP TO 8'-4" SHALL BE (4) 2x12. CONSTRUCT HEADERS PER "TYPICAL HEADER CONSTRUCTION" DETAIL." ALL HEADERS SHALL HAVE (1) TRIMMER MINIMUM AND (2) DEDICATED STUDS MINIMUM. PROVIDE (2) TRIMMERS AT OPENINGS LARGER THAN 7'-4".

LINTELS: LOOSE BRICK LINTELS FOR DOOR AND WINDOW OPENINGS UP TO 8'-4" SHALL BE L5X5X3/8 GALVANIZED (ASTM A36)

DESIGN ROOF TRUSSES TO SUPPORT RTU LOADS AT LOCATIONS SHOWN. NOTIFY ENGINEER IF WEIGHTS, SIZES, OR LOCATIONS VARY FROM THAT SHOWN.

VERIFY ALL DIMENSIONS SHOWN WITH ARCHITECTURAL DRAWINGS PRIOR TO CONSTRUCTION. INFORM ENGINEER OF ALL DISCREPANCIES.

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



5

MES WES SOURI

2023-05-23

ASI #2 07/07/2023


ROOF FRAMING PLAN


230117

Phone: (785) 291-0400 Fax: (785) 291-0401 Proj #:01190008.120 **Certificate Of Authorization** E-1392

Revit 2023 Local

STRUCTURAL ENGINEER 900 S. Kansas Avenue; Suite 400 Topeka, Kansas 66612





2


FOR PRYOR

2023-05-23

SHEET TITLE FRAMING ISOMETRIC

PROJECT NUMBER 230117


Revit 2023 Local



schwordt dosign grou

architecture interiors plant 2231 sw wanamaker rd topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102



5


SORE & SHELL BUILDING FOR STREETS OF WEST PRYOR LO

SUBMISSION DATES 2023-05-23 ASI #2 07/07/2023


SHEET TITLE
CONCRETE DETAILS &
SECTIONS I

230117


SHEET NUMBER
S-301



DBL 2x — TOP PL (20) 10d ALT: SIMPSON ST6236 STRAP TO SIDE 1. SPLICE REQUIRED OVER ALL SHEARWALLS AND ALL EXTERIOR AND BEARING WALLS. 2. SPECIFIC SPLICE REQUIREMENTS DO NOT APPLY TO INTERIOR NON-SHEARWALLS OR TOP OF PARAPET WALLS UNLESS NOTED OTHERWISE. 5 TYPICAL TOP PLATE SPLICE DETAIL SCALE: NONE



TYPICAL SHEAR BLOCKING



architecture | interiors | plannin

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

5

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115

2023-05-23

FRAMING DETAILS & SECTIONS I

230117

S-601


CERTUS = STRUCTURAL ENGINEER 900 S. Kansas Avenue; Suite 400 Topeka, Kansas 66612 Phone: (785) 291-0400 Fax: (785) 291-0401 Proj #:01190008.120

TYPICAL SHEARWALL TERMINATION TYPICAL TUBE COLUMN TO BEAM CONNECTION

SCALE: NONE 9 AT STEEL COLUMN DETAIL SCALE: NONE

STL COL, RE: PLAN-

HSS9X7X3/8 COL-



TYPICAL BM TO BM CONN TYPICAL BM TO COL CONN

TYPICAL STEEL CONNECTIONS DETAIL (SHEAR TABS)

SCALE: NONE


3@12

3@12

-HSS9X7X3/8 BM

E-1392 Revit 2023 Local


Certificate Of Authorization



schwerdt design group architecture | interiors | planning

2231 sw wanamaker rd topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115



5

LL BUILDING FOR

OF WEST PRYOR LO


SUBMISSION DATES 2023-05-23

SUMMIT,

SHEET TITLE FRAMING DETAILS & SECTIONS II

PROJECT NUMBER **230117**

SHEET NUMBER
S-602



2 S SUMMIT, MISSOURI

architecture | interiors | planning

FOR PRYOR BUILDIN F WES

> SUBMISSION DATES 2023-05-23

SHEET TITLE FRAMING DETAILS & SECTIONS III

STRUCTURAL ENGINEER 900 S. Kansas Avenue; Suite 400 Topeka, Kansas 66612 Phone: (785) 291-0400

Fax: (785) 291-0401 Proj #:01190008.120 **Certificate Of Authorization**

E-1392 Revit 2023 Local PROJECT NUMBER 230117

SHEET NUMBER

15000 - MECHANICAL SPECIFICATIONS

<u>SECTION 15000 - MECHANICAL REQUIREMENTS</u> GENERAL REQUIREMENTS

- ALL WORK SHALL BE IN ACCORDANCE W/ LATEST EDITION OF INTERNATIONAL BUILDING, MECHANICAL & PLUMBING CODES, CODES AS ADOPTED BY CITY, COUNTY, STATE & ALL OTHER APPLICABLE CODES.
- FURNISH & INSTALL ALL LABOR & MATERIALS REQUIRED FOR COMPLETE, FUNCTIONING, MECHANICAL & PLUMBING SYSTEMS W/ ALL ASSOCIATED EQUIPMENT & APPARATUS AS SHOWN ON PLANS. "PROVIDE" MEANS TO FURNISH & INSTALL.
- OBTAIN & PAY FOR ALL PERMITS REQUIRED FOR EXECUTION OF THIS WORK & SHALL MAKE ARRANGEMENTS FOR MODIFICATIONS TO WATER, GAS & SEWER CONNECTIONS TO VISIT SITE & OBSERVE CONDITIONS UNDER WHICH WORK WILL BE DONE. ANY DISCREPANCIES SHALL BE CALLED TO ARCHITECT'S ATTENTION. NO SUBSEQUENT
- ALLOWANCE WILL BE MADE IN CONTRACT FOR ANY ERROR OR NEGLIGENCE ON CONTRACTOR'S PART. FINAL ACCEPTANCE OF WORK SHALL BE SUBJECT TO CONDITION THAT ALL SYSTEMS. EQUIPMENT, APPARATUS & APPLIANCES OPERATE SATISFACTORILY AS DESIGNED &
- INTENDED. WORK SHALL INCLUDE REQUIRED ADJUSTMENT OF SYSTEMS & CONTROL FQUIPMENT INSTALLED UNDER THESE SPECIFICATIONS. WARRANT TO OWNER QUALITY OF MATERIAL, EQUIPMENT, WORKMANSHIP & OPERATION OF EQUIPMENT PROVIDED UNDER THESE SPECIFICATIONS FOR ONE YEAR FROM &
- AFTER COMPLETION OF BUILDING & ACCEPTANCE OF MECHANICAL SYSTEMS BY OWNER. ALL MATERIALS INSTALLED IN PLENUMS SHALL BE NONCOMBUSTIBLE OR HAVE FLAME/SMOKE INDEX OF NO MORE THAN 25/50 IN ACCORDANCE W/ ASTM F 84.

ROOF PENETRATIONS — MADE BY AUTHORIZED ROOFING CONTRACTOR WHEN REQUIRED.

<u>SECTION 15100 - PLUMBING</u>

- WATER PIPING ALL WATER PIPING SHALL BE 95-5 TIN-ANTIMONY JOINED TYPE L COPPER. INSULATE W/ FIBERGLASS W/ ASJ & PVC COVERS. THINCKNESS IN ACCORDANCE W/ ASHRAE 90.1.
- WASTE & VENT PIPING CI BELL & SPIGOT OR HUBLESS CI W/ NEOPRENE GASKET FITTINGS W/ STAINLESS STEEL BANDS. SCHED 40 PVC W/ SOLVENT WELDS MAY BE USED WHERE ALLOWED BY LOCAL CODE. PVC NOT ALLOWED IN PLENUMS.
- ROOF/STORM DRAIN PIPING CI BELL & SPIGOT OR HUBLESS CI W/ NEOPRENE GASKET FITTINGS W/ STAINLESS STEEL BANDS, SCHED 40 PVC W/ SOLVENT WELDS MAY BE USED WHERE ALLOWED BY LOCAL CODE. PVC NOT ALLOWED IN PLENUMS. INSULATE W/ MIN 1/2" FIBERGLASS PIPE WRAP W/ ASJ JACKET.
- GAS PIPING PROVIDE SCHED 40 CONT. WELD CARBON STEEL W/ CORRESPONDING FITTINGS. PROVIDE THREADED FITTINGS. PROVIDE IRON BODY-BRASS PLUG GAS STOPS PAINT ALL EXPOSED GAS PIPING ON THE EXTERIOR OF THE BUILDING INCLUDING ON

2. VALVES

- BALL VALVES 2" & UNDER BRONZE FULL PORT W/ TEFLOW SEATS, BRONZE BALL & INSULATED HANDLE
- BALANCING VALVES ARMSTRONG MODEL CBV I OR CBV II, 125 PSI-WP AT 250 DEGREES F., METER CONNECTIONS W/ BUILT-IN CHECK VALVES SCREWED OR FLANGED FNDS PROVIDE POLYLIRETHANE INSULATION COVER CHECK VALVES - 2" 7 SMALLER SCREWED OR SOLDER BRONZE CHECK VALVE, 200
- FLANGED, ASTM 126 IRON BODY, BRONZE TRIMMED, 200 PSI-WOG/125 PSI-WSP. BUTTERFLY VALVES - 3" & LARGER LEVER ASTM A126 CI DRILLED & TAPPED FULL LUG BODY. 200 PSI-WOG, EXTENDED NECK, BRONZE DISC, STAINLESS STEEL STEM, FIFID-REPLACEABLE FPDM SLEEVE & STEM SEALS.

PSI-WOG/125 PSI-WSP, TEFLON OR BRONZE DISC & SEAT RING. 2-1/2" & LARGER

EQUIVALENT VALVE MANUFACTURERS: MILWAUKEE, STOCKHAM, POWELL, RED-WHITE. CRANE, APPOLO, MUELLER, MUESSCO, WATTS, HAYS, ROCKWELL-NORDSTROM.

- FIXTURES: AMERICAN STANDARD, KOHLER, CRANE, ZURN, TOTO STAINLESS STEEL FIXTURES: ELKAY, JUST, MOEN COMMERCIAL
- FITTINGS & SUPPORTS: JOSAM, SMITH, WADE, ZURN, OR JONESPEC SEATS: CHURCH. OLSONITE. BEMIS OR BENEKE
- DRINKING FOUNTAINS: HALSEY TAYLOR, ELKAY, OASIS, OR HAWS. TRIM BY DELTA, ELJER, KOHLER, AMERICAN STANDARD, CRANE, SLOAN. FLUSHVALVES: SLOAN, ZURN, TOTO
- DRAINS BY WADE, ZURN, WOODFORD, SMITH, JOSAM.
- ROOF DRAINS CAST IRON ROOF DRAIN W/ FLANGE, CI MUSHROOM DOME. 2" DAM
- FOR OVERELOW DRAINS WALL HYDRANTS JOSAM SERIES 71000 W/ CONNECTIONS FOR 3/4" PIPE & HOSE. NON-FREEZING W/ KEY, VACUUM BREAKER, LOCKING COVER. EQUIVALENT BY J.R. SMITH, WADE, WOODFORD OR ZURN.

EQUIPMENT - SEE SCHEDULES

WATER HEATER - STATE, RHEEM, NATIONAL, A.O. SMITH. PORCELAINIZED GLASSLINED

TANK. COLD WATER INLET DROP TUBE. MAGNESIUM ANODE RODS. U.L. SEAL, 160 PS FACTORY TEMPERATURE & PRESSURE RELIEF VALVE. N.S.F. CONSTRUCTION. 3 YR SUBMERSIBLE SUMP PUMPS - SIMPLEX/DUPLEX SUBMERSIBLE PUMP SYSTEM AS

AUTO-RESET THERMAL /OVERLOAD PROTECTION. RECIRCULATION PUMPS - HORIZONTAL, OIL-LUBRICATED, ALL BRONZE. NON-OVERLOADING MOTOR.

SCHED/SHOWN. PUMP CASING ONE PIECE CAST IRON W/ SUPPORT LEGS, CI SUCTION

STRAINER. VERTICAL MOTOR, NEMA-6, NOT LESS THAN HP SCHED & 1750 RPM.

A. PROVIDE UNIONS OR FLANGED JOINTS IN EACH PIPE LINE PRECEDING CONNECTIONS TO EQUIPMENT TO ALLOW REMOVAL FOR REPAIR OR REPLACEMENT. PROVIDE ALL SCREWED & CONTROL VALVES W/ UNIONS ADJACENT TO FACH CONNECTION, PROVIDE SCREWED END VALVES W/ UNION ADJACENT TO VALVE UNLESS VALVE CAN BE OTHERWISE EASILY

VERIFY FLOOR MATERIALS USED FROM ARCHITECTURAL PLANS & PROVIDE PROPER

CLEANOUT TOPS, WHERE THEY OCCUR IN CARPET, QUARRY TILE, VINYL TILE OR

- REMOVED FROM LINE AFTER PIPING IS IN PLACE TEST LINES TO ENSURE NO LEAKS
- ALL PIPING & EQUIPMENT SHALL BE SUPPORTED PROPERLY FROM STRUCTURE. ESCUTCHEONS - PROVIDE NICKEL-BRASS OR CHROME PLATED ON ALL EXPOSED PIPES WHEN PASSING THRU WALL OR CEILING OF FINISHED ROOMS.
- CERAMIC TILE. PROVIDE WATER HAMMER ARRESTORS FOR ALL PLUMBING BANKS W/ FIXTURES UTILIZING FLUSH VALVES IN ANY CAPACITY. LOCATE ARRESTER BETWEEN LAST TWO FIXTURES SERVED ON BRANCH LINE.

<u>SECTION 15300 - HVAC</u>

GFNFRAI A. PROVIDE COMPLETE HVAC SYSTEM AS SHOWN ON DRAWINGS INCLUDING ALL NECESSARY EQUIPMENT, DUCTWORK, DIFFUSERS, GRILLES, & FILTERS. PROVIDE OPERATING & MAINTENANCE INSTRUCTIONS ON ALL EQUIPMENT

A. HVAC DUCTWORK SHALL BE GALV SHEET METAL OF GAUGES & JOINT TYPES SPECIFIED IN SMACNA MANUAL. PROVIDE TURNING VANES IN ELBOWS.

ALL HVAC WORK SHALL BE DONE IN STRICT ACCORDANCE W/ ALL REQUIREMENTS OF

LOCAL BUILDING CODE, ASHRAE, NEC, NFPA, & ALL OTHER APPLICABLE CODES HAVING

- VOLUME DAMPERS SHALL BE MANUAL LOCKING BLADE TYPE. ALL DUCTWORK MUST BE SUPPORTED PROPERLY FROM STRUCTURE.
- WRAP ALL SUPPLY & OUTSIDE AIR HVAC DUCTWORK W/ CERTAINTEED 1-1/2" THICK INSULATION W/ VAPOR BARRIER IN CONCEALED LOCATIONS. ALSO LINE FIRST 10' OF SUPPLY DUCTWORK FOR SOUND ATTENUATION (IN ADDITION TO WRAP) LINE ALL RETURN AIR DUCTS & TRANSFER BOOTS W/ 1/2" LINER.

- A. ROOFTOP UNITS AS SCHEDULED. EQUIVALENTS BY TRANE, CARRIER, YORK, LENNOX, AAON, DAIKIN. MIN 14" ROOF CURB. PROVIDE SLOPED CURB AS REQUIRED FOR LEVEL UNIT INSTALLATION. ECONOMIZER W/ BAROMETRIC RELIEF. FIXED DRY BULB
- CONTROL. 2" MERV 7 FILTERS. LOUVERED HAIL GUARDS. 30 DEG LOW AMBIENT. EXHAUST FANS - EQUIVALENT BY COOK, PENN, ACME, GREENHECK, JENNAIRE, TWIN CITY. PROVIDE W/ SPEED CONTROLS FOR ALL FANS LESS THAN 1/3HP TO BE FURNISHED TO E/C FOR MOUNTING AT FAN. PROVIDE W/ 14" MIN. CURB.
- PROVIDE PROGRAMMABLE THERMOSTATS W/ STAGES OF HEATING AND COOLING AS REQUIRED BY STAGES OF HEATING AND COOLING ON SPECIFIED EQUIPMENT. SEVEN (7 DAY PROGRAMMING CAPABILITY W/ 2 OCC/UNOCC PERIODS/DAY. AUTO HEAT/COOL CHANGE OVER. LOCKING SETPOINTS TO PREVENT TAMPERING. PROVIDE W/ AL INTERFACES TO OTHER EQUIPMENT AS REQUIRED. THERMOSTATS BY HONEYWELL, JOHNSON CONTROLS, WHITE-ROGERS, TRANE, CARRIER, AAON, LENNOX, DAIKIN, OR APPROVED FQUAL.

- B. COORDINATE W/ E/C TO PROVIDE ALL WIRING BETWEEN EQUIPMENT, DAMPERS, THERMOSTATS & ALL OTHER REQUIRED CONTROLS & DEVICES. PROVIDE ANY REQUIRED INTERFACES TO FIRE ALARM OR SIMILAR SYSTEMS.
- PROVIDE GROUND-MOUNTED UNITS ON 4", REINFORCED CONCRETE BASE, 4" LARGER THAN UNIT ON EACH SIDE ROOF-MOUNTED UNITS ON EQUIPMENT SUPPORTS OR CURBS. ANCHOR UNITS TO
- PROVIDE FACTORY-AUTHORIZED SERVICE START UP ON EQUIPMENT. TRAIN OWNER'S MAINTENANCE PERSONNEL ON STARTUP, SHUTDOWN, TROUBLESHOOTING, SERVICING,

16000 - ELECTRICAL SPECIFICATIONS

<u>SECTION 16000 - ELECTRICAL REQUIREMENTS</u>

GENERAL REQUIREMENTS

- A. ALL WORK SHALL BE IN ACCORDANCE W/ LATEST EDITION OF INTERNATIONAL BUILDING CODE. NATIONAL ELECTRICAL CODE, NFPA, CODES AS ADOPTED BY CITY, COUNTY, STATE & ALL OTHER APPLICABLE CODES
- B. ALL MATERIALS & EQUIPMENT SHALL BE NEW & SHALL BEAR U.L. LABEL WHERE APPLICABLE. PROVIDE WATERPROOF EQUIPMENT ENCLOSURES WHERE REQUIRED. C. OBTAIN & PAY FOR ALL PERMITS REQUIRED FOR EXECUTION OF THIS WORK & SHALL
- MAKE ARRANGEMENTS FOR MODIFICATIONS TO ELECTRICAL CONNECTIONS TO BUILDING D. CONTRACTOR SHALL PROVIDE ALL LABOR & MATERIALS REQUIRED TO HAVE COMPLETE FUNCTIONING ELECTRICAL LIGHTING & POWER SYSTEMS TOGETHER W/ ALL ASSOCIATED
- EQUIPMENT & APPARATUS AS SHOWN ON PLANS. E. WHERE AN ELECTRICAL DEVICE IS REQUIRED BY CODE BUT NOT SHOWN, IT SHALL BE PROVIDED AS THOUGH FULLY SHOWN & SPECIFIED. CONTRACTOR SHALL VISIT SITE & OBSERVE CONDITIONS UNDER WHICH WORK WILL BE
- DONE. ANY DISCREPANCIES SHALL BE CALLED TO ARCHITECT'S ATTENTION. NO SUBSEQUENT ALLOWANCE WILL BE MADE IN THIS CONNECTION FOR ANY ERROR OR NEGLIGENCE ON CONTRACTOR'S PART.
- G. FINAL ACCEPTANCE OF WORK SHALL BE SUBJECT TO CONDITION THAT ALL SYSTEMS. EQUIPMENT. APPARATUS & APPLIANCES OPERATE SATISFACTORILY AS DESIGNED & INTENDED. WORK SHALL INCLUDE REQUIRED ADJUSTMENT OF SYSTEMS & CONTROL EQUIPMENT INSTALLED UNDER THESE SPECIFICATIONS.
- H. WARRANT TO OWNER QUALITY OF MATERIALS, EQUIPMENT, WORKMANSHIP & OPERATION OF EQUIPMENT PROVIDED UNDER THESE SPECIFICATIONS FOR ONE YEAR FROM & AFTER COMPLETION OF BUILDING & ACCEPTANCE OF MECHANICAL SYSTEMS BY OWNER. I. ALL MATERIALS INSTALLED IN PLENUMS SHALL BE NONCOMBUSTIBLE OR HAVE FLAME/SMOKE INDEX OF NO MORE THAN 25/50 IN ACCORDANCE W/ ASTM E 84.

SECTION 16100 - CONDUIT & CONDUCTORS

- A. FOLLOW CIRCUITING SHOWN ON PLANS. USE NO CONDUIT SMALLER THAN 1/2" & NO CONDUCTORS SMALLER THAN #12 GA. UNLESS NOTED OTHERWISE. B. WIRE SHALL BE IN NON-FLEXIBLE METALLIC CONDUIT (EMT, IMC OR RMC) FOR ALL
- CIRCUITS AND FEEDERS GREATER THAN 30A, LIGHT SWITCH RISERS, KITCHEN CIRCUITS C. MC CABLE ACCEPTABLE FOR BRANCH CONVENIENCE CIRCUITS AND LIGHTING CIRCUITS. DO NOT DAISY CHAIN LIGHT FIXTURES. PROVIDE MC LUMINARY CABLE WITH BUILT-IN TWISTED JACKETED PAIR FOR LIGHTING CIRCUITS FOR LIGHTING CONTROLS. PROVIDE HEALTH CARE RATED MC FOR MEDICAL TREATMENT AREAS WHEN NOT IN CONDUIT.
- D. CONDUIT INSTALLED BELOW GRADE SHALL BE SCHEDULE 80 PVC HEAVY WALL PLASTIC CONDUIT MEETING NEMA STANDARDS & UL LISTED FOR UNDERGROUND & EXPOSED USE. PROVIDE GRS RADIUS BENDS & RISERS AS CONDUITS RISE ABOVE GRADE OR ABOVE FLOOR SLAB. T. PROVIDE INTERLOCKING SPACERS FOR MULT RUNS OF UG CONDUITS IN SAME TRENCH.
- F. LIGHTING & RECEPTACLE CIRCUIT CONDUCTORS SHALL BE COPPER THWN/THHN 600 VOLT. 75 DEG C. COLOR CODED AS DESCRIBED UNDER APPLICABLE CODES. NO ROMEX, PLASTIC FLEX TUBING ETC PERMITTED. LIGHT FIXTURE WIRE INSULATION SHALL HAVE TEMP RATING NOT LESS THAN INDIVIDUAL FIXTURE MANUF RECOMMENDED
- G. CIRCUITS W/ NO. 8 OR LARGER CONDUCTORS, MOTOR CIRCUITS, POWER & FEEDER CIRCUITS & BUILDING SERVICE FEEDERS SHALL BE COPPER THWN/THHN 600 VOLT,
- H. ALL CONDUIT, JUNCTION BOXES, ETC. ABOVE CEILINGS SHALL BE SUPPORTED FROM STRUCTURE. PIPE SLEEVES, HANGERS & SUPPORTS SHALL BE FURNISHED & SET & CONTRACTOR SHALL BE RESPONSIBLE FOR PROPER & PERMANENT LOCATIONS.

<u>SECTION 16200 - GROUNDING</u>

- A. SUPPLEMENT GROUNDED NEUTRAL OF SECONDARY DISTRIBUTION SYSTEM W/ EQUIPMENT GROUNDING SYSTEM, INSTALLED SO THAT METALLIC STRUCTURE'S, FNCLOSURES, RACEWAYS, JUNCTION BOXES, OUTLET BOXES, CABINETS, MACHINE FRAMES. PORTABLE EQUIPMENT & OTHER CONDUCTIVE ITEMS OPERATE CONTINUOUSLY AT GROUND POTENTIAL & PROVIDE LOW IMPEDANCE PATH FOR GROUND FAULT
- B. SYSTEM SHALL COMPLY W/ NATIONAL ELECTRICAL CODE, DRAWINGS & AS SPECIFIED. C. PROVIDE EQUIPMENT GROUND BUS IN BASE OF LOW VOLTAGE, SWITCHGEAR BRAZED OR OTHERWISE ADEQUATELY CONNECTED BY AN APPROVED METHOD TO GROUND RODS. D. PROVIDE IN CONDUIT GREEN INSULATED COPPER GROUND CONDUCTOR TO MAIN METALLIC WATER SERVICE ENTRANCE & CONNECT BY MEANS OF ADEQUATE GROUND
- E. EQUIPMENT GROUNDING CONDUCTORS FOR BRANCH CIRCUIT HOME RUNS SHOWN ON DRAWINGS SHALL INDICATE AN INDIVIDUAL & SEPARATE GROUND CONDUCTOR FOR THAT BRANCH CIRCUIT WHICH SHALL BE TERMINATED AT BRANCH CIRCUIT PANELBOARD. SWITCHBOARD. OR OTHER DISTRIBUTION EQUIPMENT.
- F. PROVIDE LOW VOLTAGE DISTRIBUTION SYSTEM W/ SEPARATE GREEN INSULATED EQUIPMENT GROUNDING CONDUCTOR FOR EACH SINGLE OR THREE-PHASE FEEDER.

SINGLE PHASE 120 VOLT BRANCH CIRCUITS FOR LIGHTING & POWER SHALL CONSIST

OF PHASE & NEUTRAL CONDUCTORS & GREEN GROUND CONDUCTOR INSTALLED IN COMMON CONDUIT WHICH SHALL SERVE AS GROUNDING CONDUCTOR. G. GROUNDING CONDUCTORS SHALL BE AS SHOWN ON PLANS OR IF NOT SPECIFICALLY

SHOWN SHALL BE NO SMALLER THAN THAT REQUIRED BY NEC. SECTION 16300 - ELECTRICAL EQUIPMENT A. JUNCTION BOXES & OUTLET BOXES SHALL BE GALVANIZED KNOCKOUT TYPF.

- LIGHTING FIXTURE BOXES IN CEILINGS SHALL NOT BE LESS THAN 4" OCTAGONAL KNOCKOUT TYPE. OUTLETS SHALL BE INSTALLED IN LOCATIONS SHOWN ON DRAWINGS EXCEPT OUTLETS MAY BE MOVED 4 FEET IN EITHER DIRECTION IF SO DIRECTED, WITHOUT ADDITIONAL COST. BOXES SHALL BE FLUSH MOUNTED ON WALLS FOR CONCEALED WORK. GANGABLE BOXES SHALL BE USED IN ALL GYPBOARD SURFACES.
- A. BRANCH CIRCUIT 208/240V PANELS SHALL BE CAPACITY SHOWN W/ TIN PLATED
- OR REQUIRED (SERIES RATED ACCEPTABLE). BOLT ON CIRCUIT BREAKERS. 480V PANELS SAME EXCEPT 25,000A AIC MIN. MINIMUM 20" WIDE W/ GALV STEEL ENCLOSURE W/ HINGED DOOR & KEYED LOCK. COORD TRIM WITH MOUNTING LOCATION. PANELS TO BE RECESSED WHENEVER POSSIBLE. B. DISTRIBUTION PANELS SHALL BE CAPACITY SHOWN & SHALL BE SQUARE D I-LINE W/

COPPER BUSSING & BRACED FOR MINIMUM OF 22,000A AIC OR AS OTHERWISE NOTED

- TIN PLASTED COPPER BUSSING. 65KAIC MIN OR AS OTHERWISE NOTED/REQ'D. BOLT ON CIRCUIT BREAKERS (SERIES RATED ACCEPTABLE). GALV STEEL ENCLOSURE. C. EQUIVALENT BY SQUARE D, SIEMENS, CUTLER HAMMER, OR GE.
- <u> SECTION 16350 ELECTRICAL IDENTIFICATION</u> A. MANUFACTURED LABELS FOR EACH PANELBOARD & TRANSFORMER. TYPEWRITTEN PANEL SCHEDULES MOUNTED IN PANELS

B. PRINTED TAPE STYLE LABEL FOR EACH RECEPTACLE INDICATING PANEL & CIRCUIT #.

C. MANUFACTURED LABELS FOR ALL DISCONNECT SWITCHES INDICATING EQUIPMENT D. BRANCH CIRCUITS - IDENTIFY EACH CIRCUIT W/ WIRE MARKERS WHEN ENCLOSURE LABEL AND WIRE COLORS DO NOT PROVIDE ENOUGH INFORMATION TO IDENTIFY EACH CIRCUIT WITHOUT TRACING. FEEDERS & BRANCH CIRCUIT HOME RUNS W/ WIRE

MARKER W/ PANEL & CKT #. BOX COVERS ABOVE LAY-IN CEILINGS NEATLY MARKED W/ INDELIBLE MARKER.

SECTION 16400 - WIRING DEVICES

- A. CONVENIENCE OUTLETS SPEC GRADE 20 AMP DUPLEX W/ GROUND & SS WALL PLATES. OTHER OUTLETS SHALL BE VERIFIED W/ EQUIPMENT SUPPLIERS FOR PROPER NEMA CONFIGURATIONS. PROVIDE GFIC RATED DEVICES WHERE INDICATED
- AND AS REO'D PER CODE. B. PROVIDE GFIC RATED DEVICES WHERE INDICATED AND ANYWHERE REQUIRED PER THE
- C. PROVIDE AFCI PROTECTION ON ALL CIRCUITS REQUIRED PER THE NEC.
- D. PROVIDE TAMPER RESISTANT RECEPTACLES ON ALL RECEPTACLES IN PUBLIC AREAS. AREAS ACCESSIBLE TO CHILDREN, AND WHERE OTHERWISE REQUIRED TO BE TAMPER RESISTANT PER THE NEC.
- E. LIGHT SWITCHES SPEC GRADE 20 AMP TOGGLE SWITCHES W/ SS WALL PLATES. F. WALL MOTION SWITCHES - SPEC GRADE, PIR, OVERRIDE. G. CEILING MOTION SWITCHES - SPEC GRADE, DUAL TECHNOLOGY, MODEL AS REQ'D BY ROOM CONFIGURATION, ALL NECESSARY POWER PACKS AND RELAYS.
- H. WALL MOTION SWITCHES (BATHROOM) DUAL RELAY, SPEC GRADE, PIR, 2ND RELAY FOR OPERATION OF EXHAUST FAN DELAY. I. COLOR OF DEVICES AS DIRECTED BY ARCHITECT.
- J. EQUIVALENT DEVICES BY LEVITON, BRYANT, HUBBEL, WATTSTOPPER, LITHONIA, SENSOR

A. ALL OUTLETS, SHALL BE MOUNTED W/ BOTTOM AT 18" AFF & SWITCHES W/ BOTTOM AT 44" ABOVE FINISHED FLOOR UNLESS NOTED OTHERWISE ON PLANS. REFER TO ARCH FOR OTHER REQUIRED ELEVATIONS AND CABINETRY COORDINATION.

<u>SECTION 16500 – LED LUMINAIRES</u>

LUMINAIRES A. PROVIDE LIGHTING FIXTURES W/ ALL ACCESSORIES REQ'D FOR HANGING. COORD MOUNTING OF LIGHTING FIXTURES W/ ARCHITECT & G/C. ADDITIONAL FIXTURE SUPPORTS SHALL BE PROVIDED BY E/C. SUPPORTS SHALL COMPLY W/ LATEST EDITION OF NEC. PROVIDE LIGHTING FIXTURE SECURING CLIPS AS REQUIRED. CONSULT ARCH PLANS FOR CEILING TYPES & PROVIDE SURFACE & RECESSED LIGHTING FIXTURES W/ APPROPRIATE MOUNTING COMPONENTS & ACCESSORIES. B. REFER TO LIGHTING FIXTURE SCHEDULE PLANS FOR FIXTURE TYPES. C. EQUIVALENT LUMINAIRES BY CREE, COOPER, HUBBELL, INFINITY, LITHONIA, WILLIAMS, COLUMBIA, EXITRONICS, LITEALARM, EXIDE, MULE, DUALLITE

ARRREVIATIONS

DF DRINKING FOUNTAIN

DN DOWN

EA EXHAUST AIR

ELEV ELEVATION

DHW DOMESTIC HOT WATER

E/C ELECTRICAL CONTRACTOR

EM EMERGENCY FIXTURE/DEVICE

DHWR DOMESTIC HOT WATER RETURN

DIVENIATIONS				
ARCHITECT / ENGINEER	EWT	ENTERING WATER TEMPERATURE	PSI	POUNDS PER SQUARE INCH
ABOVE FINISHED FLOOR	EΧ	EXISTING ITEM	PVC	POLYVINYLCHLORIDE
ABOVE FINISHED GRADE	FFA	FROM FLOOR ABOVE	RA	RETURN AIR
ABOVE GRADE	FFB	FROM FLOOR BELOW	RE/REF	REFER / REFERENCE
AUTHORITY HAVING JURISDICTION	FFC0	FINISHED FLOOR CLEAN OUT	RF	RELIEF FAN
ARCHITECT	FGC0	FLUSH GRADE CLEAN OUT	RL	RELOCATED ITEM
BACKFLOW PREVENTER	FL	FLOW LINE	RPZ	REDUCED PRESSURE ZONE
BELOW GRADE	FLR	FLOOR	RR	RESTROOM
BUILDING	FPM	FEET PER MINUTE	SA	SUPPLY AIR
BUILDING MANAGEMENT SYSTEM	FWC0	FLUSH WALL CLEAN OUT	SPD	SURGE PROTECTIVE DEVICE
CONDUIT	G	GROUND / GANG	TA	TRANSFER AIR
CANDELA	G/C	GENERAL CONTRACTOR	TFA	TO FLOOR ABOVE
COLD DECK	ĠFCI	GROUND FAULT CIRCUIT INTERUPTER	TFB	TO FLOOR BELOW
COOLING	GPM	GALLONS PER MINUTE	ΤP	TAMPERPROOF
COORDINATE MOUNTING HEIGHT	HD	HOT DECK	TYP	TYPICAL
CLEAN OUT	HTG	HEATING	UNO	UNLESS NOTED OTHERWISE
CONNECT TO EXISTING	IG	ISOLATED GROUND	VTR	VENT THROUGH ROOF
DOUBLE CHECK VALVE ASSEMBLY	JB	JUNCTION BOX	WP	WEATHERPROOF
DOMESTIC COLD WATER	LED	LIGHT EMITTING DIODE		
DIRECT DIGITAL CONTROLS	LWT	LEAVING WATER TEMPERATURE		
	ARCHITECT / ENGINEER ABOVE FINISHED FLOOR ABOVE FINISHED GRADE ABOVE GRADE AUTHORITY HAVING JURISDICTION ARCHITECT BACKFLOW PREVENTER BELOW GRADE BUILDING BUILDING MANAGEMENT SYSTEM CONDUIT CANDELA COLD DECK COOLING COORDINATE MOUNTING HEIGHT CLEAN OUT CONNECT TO EXISTING DOUBLE CHECK VALVE ASSEMBLY DOMESTIC COLD WATER	ARCHITECT / ENGINEER EWT ABOVE FINISHED FLOOR EX ABOVE FINISHED GRADE FFA ABOVE GRADE FFB AUTHORITY HAVING JURISDICTION FFCO ARCHITECT FGCO BACKFLOW PREVENTER FL BELOW GRADE FLR BUILDING FPM BUILDING MANAGEMENT SYSTEM FWCO CONDUIT G CANDELA G/C COLD DECK GFCI COOLING GPM COORDINATE MOUNTING HEIGHT HD CLEAN OUT HTG DOUBLE CHECK VALVE ASSEMBLY JB DOMESTIC COLD WATER LED	ARCHITECT / ENGINEER ABOVE FINISHED FLOOR ABOVE FINISHED GRADE ABOVE GRADE AUTHORITY HAVING JURISDICTION ARCHITECT BACKFLOW PREVENTER BUILDING BUILDING BUILDING CANDELA COLD DECK COOLING CONDIT CONDIT CONDIT CONDIT CONDIT CONDIT CONDITA CONDINATE MOUNTING HEIGHT HD HOT DECK CLEAN OUT CONNECT TO EXISTING DOUBLE CHECK VALVE ASSEMBLY DOMESTIC COLD WATER LED LIGHT EMITTING DIODE	ARCHITECT / ENGINEER ABOVE FINISHED FLOOR EX EXISTING ITEM PVC ABOVE FINISHED GRADE ABOVE GRADE ABOVE GRADE ABOVE GRADE AUTHORITY HAVING JURISDICTION FFCO BACKFLOW PREVENTER BUILDING BELOW GRADE FIR BUILDING FPM FET FL FLOOR FFM FET FLOOR FFM FET FLOOR BUILDING FPM FET FLOOR FFM FET FUON FET FUON FOR BUILDING FPM FET FUON FET FUNITE FOR GROUND GRADE GROUND GRADE FOR GROUND GRADE FOR GROUND GROUND FOR FOR FOR FOR FOR FOR FOR FO

M/C MECHANICAL CONTRACTOR

MCB MAIN CIRCUIT BREAKER

ORD OVERFLOW ROOF DRAIN

P/C PLUMBING CONTRACTOR

MECH MECHANICAL


MLO MAIN LUGS ONLY


NFA NET FREE AREA

OA OUTSIDE AIR

ELECTRICAL SYMBOL LEGEND SOME SYMBOLS AND ABBREVIATIONS ON THIS LEGEND MAY NOT BE USED CIRCUITING POWER DEVICES HOME RUN (2#12 1#12G UNO) \bigcirc DUPLEX RECEPTACLE. INDICATES 2 PHASE, 1 N, & 1 GRD CONDUCTOR LINE THRU DEVICE INDICATES ABOVE COUNTER SPECIAL DUPLEX RECEPTACLE HOME RUN: INDICATES SHARED CIRCUIT (GFCI, ISOLATED GROUND, ETC.) HOME RUN: INDICATES #10 CONDUCTORS ENTIRELY QUADPLEX RECEPTACLE SIMPLEX RECEPTACLE W/NEMA CONFIG AS NOTED --- UGE --- UNDERGROUND ELECTRICAL MULTI-POLE RECEPTACLE W/NEMA CONFIG AS NOTED ---- OHE ---- OVERHEAD ELECTRICAL CEILING MOUNTED RECEPTACLE ---- TELE ---- TELECOMMUNICATIONS CONDUIT RECEPTACLE/DEVICE MOUNTED IN "TOMBSTONE" --- UGT --- UNDERGROUND TELECOMMUNICATIONS CONDUIT POKE-THRU WITH POWER <u>LIGHTING</u> POKE-THRU WITH TELECOMMUNICATIONS POKE-THRU W/POWER AND TELECOM ├□ ├○ WALL-MOUNTED LIGHT FIXTURE SINGLE GANG FLOOR BOX (2, 3, 4 GANG SIMILAR) POLE-MOUNTED LIGHT FIXTURE DIVIDED POWER POLE TIMECLOCK - REFER TO PLANS / DETAILS CLOCK RECEPTACLE <u>EQUIPMENT</u> PLUG MOLD / WIRE MOLD AS SPECIFIED \Box DISCONNECT SWITCH. RE: PLANS FOR INFORMATION. JUNCTION BOX MAGNETIC MOTOR STARTER THERMOSTAT - ELECTRIC COMBINATION DISCONNECT SWITCH / MOTOR STARTER \Box H PUSH BUTTON TOGGLE-TYPE DISCONNECT FURNISH WITH THERMAL MOTOR PROTECTION WHERE SERVING FANS/PUMPS. SURFACE PANELBOARD

FIRE ALARM RECESSED PANELBOARD DUCT SMOKE DETECTOR DISTRIBUTION PANELBOARD SWITCHBOARD. FEEDER/MAIN CIRCUIT BREAKER SECTION AND DISTRIBUTION SECTION. GENERAL SYMBOLS INDICATES CONNECT TO EXISTING





CHECK VALVE INLINE STRAINER TEST PLUG

HI LOW
PRESSURE REDUCING VALVE

SPECIFICATIONS

SHEET NUMBER **ME-101**

2949 SW WANAMAKER DR., TOPEKA, KANSAS 66614 785.273.2447 WWW.PKMRENG.COM

PLUMBING FIXTURES/EQUIPMENT → HB HOSE BIBB — ₩H WALL HYDRANT ——□ □ CLEAN OUT REDUCED PRESSURE BACKFLOW PREVENTER DOUBLE CHECK BACKFLOW PREVENTER

FS: FLOOR SINK

PLUMBING FIXTURE AND CALLOUT RD: ROOF DRAIN ORD: OVERFLOW ROOF DRAIN

PIPING SPECIALTIES

SUBMISSION DATES MAY 23, 2023 JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2

SHE

ORE

lschwerdt design group

architecture interiors planning

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540

BRYAN

LEINWETTER

NUMBER

PE-2020020297

suite 200

6408

OURI

ဟ

9

0

C

ES SU

fax: 785.273.7579

fax: 405.231.3115

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105

FEB 19, 2024 - ASI 5/ SHEET TITLE MECHANICAL AND ELECTRICAL

AUGUST 7, 2023-ASI 4

TRE

PROJECT NUMBER 230117

FIRE SEALING NOTES

AUTHORITIES HAVING JURISDICTION.

- 1. COORDINATE CONSTRUCTION OF OPENINGS AND PENETRATING ITEMS TO ENSURE THAT THROUGH-PENETRATION FIRESTOP SYSTEMS ARE INSTALLED ACCORDING TO SPECIFIED AND APPLICABLE UL
- REQUIREMENTS. 2. COORDINATE SIZING OF SLEEVES, OPENINGS, CORE-DRILLED HOLES,
- OR CUT OPENINGS TO ACCOMMODATE THROUGH—PENETRATION 3. DO NOT COVER UP THROUGH-PENETRATION FIRESTOP SYSTEM INSTALLATIONS UNTIL EXAMINED BY NSPECTOR, IF REQUIRED BY
- 4. COMPATIBILITY: PROVIDE THROUGH—PENETRATION FIRESTOP SYSTEMS THAT ARE COMPATIBLE WITH ONE ANOTHER; WITH THE SUBSTRATES FORMING OPENINGS: AND WITH THE ITEMS, IF ANY, PENETRATING THROUGH-PENETRATION FIRESTOP SYSTEMS, UNDER CONDITIONS OF SERVICE AND APPLICATION, AS DEMONSTRATED BY THROUGH-PENETRATION FIRESTOP SYSTEM MANUFACTURER BASED ON
- TESTING AND FIELD EXPERIENCE. 5. PROVIDE COMPONENTS FOR EACH THROUGH—PENETRATION FIRESTOP SYSTEM THAT ARE NEEDED TO INSTALL FILL MATERIALS. USE ONLY COMPONENTS SPECIFIED BY THROUGH-PENETRATION FIRESTOP SYSTEM MANUFACTURER AND APPROVED BY QUALIFIED TESTING AND INSPECTING AGENCY FOR FIRESTOP SYSTEMS INDICATED.
- 6. PROVIDE SLEEVES THROUGH ALL FIRE_RATED WALLS AND FILL VOIDS SURROUNDING SLEEVES AND INTERIOR TO SLEEVES AROUND PIPING WITH FIRE STOP PUTTY WITH U.L. LISTED 3 HOUR RATING INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS.
- 7. FIRE SEAL ALL PIPING, CONDUIT, CABLE, ETC PENETRATIONS ROUTED THROUGH FIRE RATED WALLS.
- 8. PROVIDE FIRE RATED ENCLOSURES OR WRAPS ON LIGHT FIXTURES AND OTHER ITEMS PENETRATING FIRE RATED CEILINGS, FLOOR/CEILING/ CEILING/ROOF ASSEMBLIES TO MAINTAIN UL LISTING FOR CONSTRUCTION.

GENERAL ELECTRICAL NOTES

- 1. COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE LATEST ADOPTED VERSION OF THE NATIONAL ELECTRICAL CODE, LOCAL AND STATE CODES, AND REQUIREMENTS OF THE AHJ.
- 2. COORDINATE LOCATIONS OF RECEPTACLES, SWITCHES, ETC. WITH ARCHITECTURAL CASEWORK AND ELEVATIONS.
- 3. REFER TO MOUNTING HEIGHTS DETAIL FOR MOUNTING HEIGHTS OF ALL DEVICES NOT INDICATED OTHERWISE. 4. PROVIDE ALL EMPTY CONDUITS WITH PULL STRINGS AND BUSHED
- 5. CONTRACTOR SHALL CONCEAL ALL CONDUIT, FITTINGS, AND DEVICES FROM VIEW WHERE REASONABLY POSSIBLE.

GENERAL NOTES

- 1. SOME ROOM NAMES MAY NOT BE SHOWN FOR PURPOSE OF CLARIFYING PLAN. REFER TO ARCHITECTURAL PLANS FOR REFERENCE TO ROOM NAMES NOT SHOWN.
- 2. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO MAINTAIN AND KEEP AT THE JOB SITE, AN UP TO DATE SET OF "RECORD DRAWINGS" SHOWING ALL CHANGES FROM THE ORIGINAL PLANS. THE CONTRACTOR SHALL DELIVER THE "RECORD DRAWINGS" TO THE ENGINEER AT THE CONCLUSION OF THE PROJECT ELECTRONICALLY.
- 3. THESE DRAWINGS ARE DIAGRAMMATIC. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS (NEW AND EXISTING), DIMENSIONS, AND CLEARANCES PRIOR TO THE COMMENCEMENT OF WORK AND SHALL INCLUDE ALL COSTS, EQUIPMENT, MATERIAL, ACCESSORIES, ETC. REQUIRED FOR A FULLY COMPLETE, FUNCTIONAL AND CODE COMPLIANT INSTALLATION.
- 4. FINAL LOCATIONS OF ALL DEVICES, LIGHT FIXTURES, EQUIPMENT ETC SHALL BE INDICATED ON THE ARCHITECTURAL DRAWINGS. ALL DIMENSIONAL INFORMATION SHALL BE OBTAINED FROM ARCHITECTURAL PLANS. NO DIMENSIONAL INFORMATION SHALL BE OBTAINED FROM MEP DRAWINGS.
- 5. THE CONTRACTOR SHALL OBTAIN ALL REQUIRED PERMITS. APPROVALS, LICENSES, ETC. AS NEEDED FOR THE COMPLETE INSTALLATION AND PROJECT. THE CONTRACTOR SHALL COORDINATE WITH THE OWNER FOR ALL FEES AND DATA NEEDED FOR THIS.

GEN. MECHANICAL NOTES

- 1. COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE LATEST ADOPTED VERISION OF THE INTERNATIONAL MECHANICAL CODE, LOCAL AND STATE CODES, AND REQUIREMENTS OF THE AHJ.
- 2. ANY POWER FOR CONTROL SYSTEMS TO BE PROVIDED BY E/C IS INDICATED ON ELECTRICAL PLANS. ANY ADDITIONAL LINE VOLTAGE OR LOW VOLTAGE POWER REQUIRED BY THE M/C OR SUBCONTRACTORS TO HAVE A FULLY FUNCTIONING SYSTEM SHALL BE PROVIDED BY THE M/C CONTRACTOR OR SUBS.
- 3. ALL EQUIPMENT SHALL BE ADEQUATELY AND PROPERLY SUPPORTED AND FASTENED FROM STRUCTURE.
- 4. ALL EQUIPMENT AND ACCESSORIES INSTALLED IN CONCEALED SPACES REQUIRING ACCESS SHALL BE PROVIDED WITH ACCESS DOORS MEETING ANY FIRE REQUIREMENTS OF THE WALL/CEILING THEY ARE INSTALLED.
- 5. EACH AIR HANDLING UNIT OVER 2000CFM SHALL BE PROVIDED WITH A SMOKE DETECTOR TO SHUT DOWN THE UNIT PER IMC 606 AS REQUIRED BY AHJ. COORDINATE WITH OTHER TRADES.
- 6. START UP AND ADJUST ALL EQUIPMENT AND VERIFY ALL MECHANICAL SYSTEMS IN OPERATE IN ACCORDANCE WITH THEIR INTENDED PURPOSES. SUBMIT BALANCE AND START UP REPORTS TO THE A/E. REFER TO SPECIFICATIONS FOR ANY ADDITIONAL REQUIREMENTS.

GENERAL PLUMBING NOTES

- 1. COMPLETE INSTALLATION SHALL BE IN ACCORDANCE WITH THE LATEST ADOPTED VERISION OF THE INTERNATIONAL PLUMBING CODE, LOCAL AND STATE CODES, AND REQUIREMENTS OF THE AHJ. 2. NO PIPING SHALL BE INSTALLED WHERE IT WILL SUBJECT TO
- FREEZING TEMPERATURES. PIPING IN EXTERIOR WALLS SHALL BE INSTALLED ON THE WARM SIDE OF BUILDING INSULATION, INSULATED AND THE CHASE SHALL BE VENTILATED WITH GRILLES ALLOWING INDOOR AMBIENT CONDITIONS TO CIRCULATE THROUGH THE CHASE. 3. PROVIDE CLEANOUTS IN THE FOLLOWING LOCATIONS:
- 3.1. IN ALL HORIZONTAL DRAINS (WITHIN THE BUILDING) NOT MORE THAN 100 FEET APART.
- 3.2. IN BUILDING SEWERS LOCATED NO MORE THAN 100 FEET APART MEASURED FROM THE UPSTREAM ENTRANCE OF THE CLEANOUT. 3.3. EACH CHANGE OF DIRECTION OF THE BUILDING DRAIN OR
- HORIZONTAL WASTE OR SOIL LINES GREATER THAN 45 DEGREES.WHERE MORE THAN ONE CHANGE OF DIRECTION OCCURS IN A RUN OF PIPING, ONLY ONE CLEANOUT SHALL BE REQUIRED FOR EACH 40 FEET OF DEVELOPED LENGTH OF THE DRAINAGE
- 3.4. AT THE BASE OF EACH WASTE OR SOIL STACK.
- 3.5. NEAR THE JUNCTION OF THE BUILDING DRAIN AND BUILDING SFWFR.

COORDINATION NOTES


- 1. COORDINATE REQUIREMENTS FOR INSTALLATION OF SYSTEMS AND EQUIPMENT WITH ALL OTHER TRADES.
- 2. THE CONTRACTOR SHALL COORDINATE THE ROUTING AND PATH OF ALL SYSTEMS, CONDUITS, PIPES, DUCTS, ETC WITH THE POSITION AND LAYOUT OF THE STRUCTURE. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING NECESSARY OFFSETS, TURNS, RISES AND DROPS FOR SYSTEMS AND COMPONENTS AS NEEDED TO INSTALL THE MEP SYSTEMS TO CLEAR STRUCTURE, CEILINGS, ETC AND OTHER SYSTEMS IN POTENTIAL CONFLICT WITH ROUTING.
- 3. COORDINATE WORK WITH OTHER TRADES TO INSTALL SYSTEMS ABOVE CEILING HEIGHTS INDICATED ON ARCHITECTURAL PLANS.
- 4. CHECK SPACE REQUIREMENTS WITH OTHER TRADES AND STRUCTURE/CONSTRUCTION TO INSURE THAT ALL MATERIALS AND EQUIPMENT CAN BE INSTALLED IN THE SPACE ALLOTTED INCLUDING FINISHED SUSPENDED CEILINGS AND OTHER SPACES, CHASES, ETC WITHIN THE BUILDING. MAKE MODIFICATIONS THERETO AS REQUIRED
- 5. TRANSMIT TO OTHER TRADES ALL INFORMATION REQUIRED FOR WORK TO BE PROVIDED UNDER THEIR RESPECTIVE SECTIONS IN AMPLE

AND APPROVED.


- 6. WHEREVER WORK INTERCONNECTS WITH WORK OF OTHER TRADES, COORDINATE WITH THOSE TRADES TO INSURE THAT ALL SUBCONTRACTORS HAVE THE INFORMATION NECESSARY SO THAT THEY MAY PROPERLY INSTALL ALL CONNECTIONS AND EQUIPMENT. IDENTIFY ALL ITEMS OF WORK THAT REQUIRE ACCESS SO THAT THE CEILING TRADE WILL KNOW WHERE TO INSTALL ACCESS DOORS AND
- 7. COORDINATE, PROJECT AND SCHEDULE WORK WITH OTHER TRADES IN ACCORDANCE WITH THE CONSTRUCTION SEQUENCE.
- 8. DRAWINGS SHOW THE GENERAL RUNS OF CONDUITS, PIPING AND DUCTWORK AND APPROXIMATE LOCATION OF OUTLETS. ANY SIGNIFICANT CHANGES IN LOCATION OF ITEMS NECESSARY IN ORDER TO MEET FIELD CONDITIONS SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE ARCHITECT/ENGINEER AND RECEIVE HIS APPROVAL BEFORE SUCH ALTERATIONS ARE MADE. ALL SUCH MODIFICATIONS SHALL BE MADE WITHOUT ADDITIONAL COST TO THE OWNER.
- 9. CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTION AND REPAIR OF SURFACES, AREAS AND PROPERTY THAT MAY BE DAMAGED AS A RESULT OF CONSTRUCTION ACTIVITIES.
- 10. ADJUST LOCATION OF PIPING, DUCTWORK, ETC. TO PREVENT INTERFERENCES, BOTH ANTICIPATED AND ENCOUNTERED. DETERMINE THE EXACT ROUTE AND LOCATION OF EACH ITEM PRIOR TO FABRICATION. MAKE OFFSETS, TRANSITIONS AND CHANGES IN DIRECTION IN SYSTEMS AS REQUIRED TO MAINTAIN ADEQUATE CLEARANCES AND HEADROOM.
- 11. WHEREVER THE WORK IS OF SUFFICIENT COMPLEXITY, PREPARE ADDITIONAL COORDINATION DRAWINGS AND ORGANIZE ON-SITE MEETINGS WITH ALL RELATED SUBCONTRACOTRS TO COORDINATE THE WORK BETWEEN TRADES . DRAWINGS SHALL CLEARLY SHOW THE WORK AND ITS RELATION TO THE WORK OF OTHER TRADES, AND BE SUBMITTED FOR REVIEW PRIOR TO COMMENCING SHOP FABRICATION OR ERECTION IN THE FIELD.
- 12. COORDINATE WITH LOCAL UTILITY PROVIDERS FOR THEIR REQUIREMENTS FOR SERVICE CONNECTIONS AND PROVIDE ALL NECESSARY PAYMENTS, MATERIALS, LABOR AND TESTING TO ACCOMPLISH THE WORK.

∕LIGHT POLE

LIGHT FIXTURE



 $+^{0.1}$ $+^{0.3}$ $+^{0.8}$ $+^{1.2}$ $+^{1.3}$ $+^{1.3}$ $+^{1.4}$ $+^{1.3}$ $+^{1.3}$ $+^{1.2}$ $+^{0.9}$ $+^{0.5}$ $+^{0.5}$ $+^{0.8}$ $+^{1.5}$ $+^{2.5}$ $+^{2.9}$ $+^{3.3}$ $+^{2.9}$



LIGH	IT FIXTUR	E SCHEDULE					
PLAN MARK	MANUFACTURER	MODEL NUMBER MOUNTING FINISH		LAMP CODE	LAMP QUANTITY	NOTES	
AA	MCGRAW-EDISON	GALN-SA2C-740-U-T4FT-2@180 DEG	20' POLE	BRONZE	216 LED PER HEAD	2	1,2,3,5
BB	MCGRAW-EDISON	GALN-SA2C-740-U-T4FT	20' POLE	BRONZE	216 LED PER HEAD	1	1,2,3,5
Α	LITHONIA	WPX1-LED-P2-30K-MVOLT-E14WC-DDBXD	WALL/SURFACE	BRONZE	24W LED	_	1,2
В	GREEN CREATIVE	12NCDRL6DIM/930/EXT	RECESSED	BLACK	12W LED	-	1,2,3,6
B1	GREEN CREATIVE	12NCDRL6DIM/930/EXT-EM	RECESSED	BLACK	12W LED	-	1,2,3,4,6
С	AFX	BMW517800L30MVBZ	WALL/SURFACE	BRONZE	1,800 LUMENS/19W	_	1,2

NOTES LEGEND

- 1 PROVIDE WET LOCATION RATED FIXTURE
- 2 PROVIDE COLD LOCATION RATED DRIVER
- 3 PROVIDE SQUARE STRAIGHT STEEL POLE RATED FOR 100 MPH WIND GUSTS, PRIMED AND PAINTED TO MATCH FIXTURE

ANCHOR BOLT, BY-LIGHT POLE SUPPLIER

(8) #5 VERT EQ SPA →

#4 TIES @12 OC-

- 4 PROVIDE EMERGENCY BATTERY
- 5 PROVIDE ALL ACCESSORIES FOR A COMPLETE INSTALLATION. 6 - PROVIDE WEATHER PROOF JUNCTION BOX FOR DRIVERS AND ELECTRICAL CONNECTIONS ABOVE SOFFIT.





schwerdt design group architecture interiors planning

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579 500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115

BRYAN LEINWETTER NUMBER PE-2020020297

6408 OURI S

0 C

ORE

SUBMISSION DATES JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2

AUGUST 7, 2023-ASI 4 FEB 19, 2024 - ASI (

SHEET TITLE SITE PHOTOMETRIC PLAN AND GENERAL NOTES


PROJECT NUMBER 230117

SHEET NUMBER

SITE PLAN - LIGHTING

785.273.2447

ME-201





500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115 NUMBER PE-2020020297

BRYAN LEINWETTER

COUNTY ETS OF WEST

WENSTEIN DR, LEES SUMM

SUBMISSION DATES

MAY 23, 2023


JUNE 12, 2023-REV 1

JULY 7, 2023-ASI 2 AUGUST 7, 2023-ASI 4

SHEET TITLE
SITE MEP PLAN

PROJECT NUMBER **230117**

SHEET NUMBER
ME-202



schwerdt design group architecture interiors planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579


SOURI 64081 MIS OUNTY

SUBMISSION DATES JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2 AUGUST 7, 2023-ASI 4

PLUMBING FLOOR

PROJECT NUMBER 230117


SHEET NUMBER M-101



				T T			T I		Г	г				1	I	
PLAN MARK	MANUFACTURER	MODEL NUMBER	SIZE	REFRIGERANT	MINIMUM EFFICIENCY	AIRFLOW	COMPRESSORS	COOLING CAPACITY	CFM	EXTERNAL STATIC	OA CFM	HEATING CAPACITY	ELECTRICAL	WEIGHT	FILTER	NOTE
RTU-1	TRANE	YSC 048 E3	4 TON	R-410A	14 SEER	DOWN	(1) SCROLL	49,000 BTUH	1,600	0.7"	160	80 MBH	208 V., 3 PH, 35 AMP	800 LBS	MERV 13	1,2,3,
RTU-2	TRANE	YSC 048 E3	4 TON	R-410A	14 SEER	DOWN	(1) SCROLL	49,000 BTUH	1,600	0.7"	160	80 MBH	208 V., 3 PH, 35 AMP	800 LBS	MERV 13	1,2,3,
RTU-3	TRANE	YSC 048 E3	4 TON	R-410A	14 SEER	DOWN	(1) SCROLL	49,000 BTUH	1,600	0.7"	160	80 MBH	208 V., 3 PH, 35 AMP	800 LBS	MERV 13	1,2,3,4
RTU-4	TRANE	YSC 060 E3	5 TON	R-410A	14 SEER	DOWN	(1) SCROLL	60,100 BTUH	2,000	1.0"	200	80 MBH	208 V., 3 PH, 40 AMP	800 LBS	MERV 13	1,2,3,
RTU-5	TRANE	YSC 072 E3	6 TON	R-410A	14.6 IEER	DOWN	(1) SCROLL	75,000 BTUH	2,400	1.1"	240	120 MBH	208 V., 3 PH, 50 AMP	1000 LBS	MERV 13	1,2,3,4
RTU-6	TRANE	YSC 048 E3	4 TON	R-410A	14 SEER	DOWN	(1) SCROLL	49,000 BTUH	1,600	0.7"	160	80 MBH	208 V., 3 PH, 35 AMP	800 LBS	MERV 13	1,2,3,

NOTES LEGEND 1. PROVIDE ROOF CURB, DISCONNECT SWITCH, HAIL GUARDS, AND ECONOMIZER

2. PROVIDE WALL MOUNTED 7-DAY PROGRAMMABLE THERMOSTAT





schwerdt design group architecture interiors planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115 BRYAN LEINWETTER NUMBER PE-2020020297

SOURI 64081 5 OUNT


5 **—** ES SUI ORE

SUBMISSION DATES MAY 23, 2023 JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2 AUGUST 7, 2023-ASI 4 FEB 19, 2024 - ASI 5/6

SHEET TITLE HVAC FLOOR PLAN

PROJECT NUMBER 230117

SHEET NUMBER



schwerdt design group architecture interiors planning 2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115 BRYAN LEINWETTER NUMBER PE-2020020297

6408

OURI OUNT ES SUI

SUBMISSION DATES JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2 AUGUST 7, 2023-ASI 4 FEB 19, 2024 - ASI 5 MARCH 13, 2024 - ASI 6 / 7

S


0

SHEET TITLE POWER FLOOR PLAN

PROJECT NUMBER 230117

SHEET NUMBER

E-101




MOUNT TYPE "A" FIXTURES AT 8'-6" AFF UNO

DOUBLE-SECTION PANELBOARD SCHEDULE PANEL DESIGNATION | MAIN BUS AMPS: 200 VOLTAGE: 120/208V MOUNTING: RECESSED MAIN BREAKER: 200 PHASE/WIRE: 3PH/4W LOCATION: SEE PLAN PANEL TYPE: NQOD CIRCUIT DESCRIPTION ROOF RECEPTACLES | 35 | 3 | RTU-3 SPARE RTU-5 SPARE SPARE SPARE SPARE
 16
 20
 1
 SPARE

 18
 20
 1
 SPARE
 SPARE SPARE SPARE SPARE SPARE SPARE 16 20 1 SPARE SPARE 28 **20 1 SPARE** SPARE 0 20 1 SPARE SPARE SPARE 34 **20 1** SPARE SPARE SPARE 6 20 1 SPARE 8 20 1 SPARE SPARE 40 20 1 SPARE SPARE

12 **20 1**



SUITE B

SUBMISSION DATES
JUNE 12, 2023-REV 1 JULY 7, 2023-ASI 2 AUGUST 7, 2023-ASI 4 FEB 19, 2024 - ASI 5 MARCH 13, 2024 - ASI 6 / 7 SHEET TITLE LIGHTING FLOOR PLAN PROJECT NUMBER **230117** SHEET NUMBER

architecture interiors planning

2231 sw wanamaker rd suite 303 topeka, kansas 66614-4275 phone: 785.273.7540 fax: 785.273.7579

NUMBER

SOURI 64081

OUNT

9

ETS OF WEST

WENSTEIN DR, LEES SUN

CORE & SHELL BU
STREETS OF V
2070 NW LOWENSTEIN DR, L

E-201

500 north broadway oklahoma city, ok 73102 phone: 405.231.3105 fax: 405.231.3115

PEARSON KENT MCKINLEY RAAF ENGINEERS LLC 2949 SW WANAMAKER DR., TOPEKA, KANSAS 66614 785.273.2447 WWW.PKMRENG.COM

5

CIRCUIT THROUGH PHOTOCELL ON AND TIMECLOCK OFF