CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233281

Address: 2630 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Tuesday, April 09, 2024

Residential

Corrective Action Required:

1 Misc

- -provide as graded plot plan
- -obtain issued lawn irrigation permit
- -water meter to be 14"-18" from top of meter to well lid ring
- -Obtain vegetation in swale at rear of lot

Comments: