

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Passed	Tuesday, April 09, 2024

Informational:

1	Miscellaneous Correction	-Party wall passed inspection -Screw pattern will need to be scheduled for a rated assembly inspection.
---	-----------------------------	--

This is a partial pass only

Corrective Action Required:

2	Miscellaneous Correction	Screws are missing along wall in bedroom 1 in unit 2218 (east side)
---	-----------------------------	---

Comments: