

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230682
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Patrick Schonfeldt	Passed	Wednesday, April 10, 2024

Informational:	
1 Misc	4-10-24 PS Observed air test of sanitary lines - lines passed testing requirements
	EX MH# 60-163 to SS 1-1 - Passed
	SS 1-1 to SS 1-2 - Passed
	SS 1-2 to SS 1-3 - Passed
	SS 1-3 to SS 1-4 - Passed
	SS 1-4 to SS 1-5 - Passed

Comments: