

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOMCOM20230057

Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081443 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081445 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081447 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081449 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081453 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081441 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Shawn Hoffman	Failed	Wednesday, April 10, 2024

Corrective Action Required:

1	E110.22 Identification of disconnection means	Each disconnecting means shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. The marking shall be of sufficient durability to withstand the environment involved. Where circuit breakers or fuses are applied in compliance with the series combination ratings marked on the equipment by the manufacturer, the equipment enclosure(s) shall be marked in the field to indicate the equipment has been applied with a series combination rating. The marking shall be readily visible and state the following: CAUTION-SERIES COMBINATION SYSTEM RATED ____AMPERES. IDENTIFIED REPLACEMENT COMPONENTS REQUIRED.
---	--	---

EACH UNIT

Comments: