CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235258

Address: 817 NE ALGONQUIN ST, LEES SUMMIT, MO 64064819 NE ALGONQUIN ST, LEES SUMMIT, MO

64064815 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Khanh Nguyen Failed Wednesday, April 10,

2024

Corrective Action Required:

1 Misc Provide 2-he separation at roof soffits

Comments: