

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222783  
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Robb Popp	Partial	Wednesday, April 10, 2024

Partial Correction:

1	Misc	-Sanitary line between lines M and N complete to exterior -Sanitary line between lines Y and Z complete to exterior -Sanitary line between lines A and B from lines 3 to 5 complete to exterior **Install cleanouts at exterior of building  -Sanitary line branch south of line 4 from center 100' east and west between lines H and S ****UPDATE PLANS TO REFLECT CHANGES
---	------	---

Comments: