



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20111353, Building Permit - Commercial
Address: 122 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Friday, August 26, 2011

Corrective Action Required

1 MISC

ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED HANG ADDRESS-STAMPED MEDALLIONS ON LOAD SIDE PIPES.

Corrective Action Required

2 MISC

ADDRESS LABELING OF ELECTRICAL SERVICE METER/DISCONNECT: APPLY PERMANENT ADDRESS STICKER

Corrective Action Required

3 MISC

SEAL HOLES, PENETRATIONS, ANNULAR SPACES IN EXTERIOR WALL AND SOFFIT (AT PIPE, CONDUIT, CABLES...)

Corrective Action Required

4 MISC

PIPING OF WATER HEATER TPR DISCHARGE: PIPE MATERIAL MUST BE RATE FOR HIGH TEMPERATURE; MUST PIPE DIRECTLY TO FLOOR DRAIN OR FLOOR -- NOT TO PLASTIC PAN

Corrective Action Required

5 MISC

UNUSED OPENING AT ELECTRICAL JUNCTION BOX @ EAST MECH RM NW CORNER REQUIRES PLUG

Corrective Action Required

6 MISC

WATER PIPE SUPPORT FLANGE BEHIND WATER HEATER @ EAST MECH RM NOT ANCHORED TO WALL

Corrective Action Required

7 MISC

WATER UTILITES DEPARTMENT MAY REQUIRE TESTING INFO FOR BACKFLOW PREVENTION DEVICES -- CARD PROVIDED FOR BEN HASKAMP

Corrective Action Required

8

MISC

RESOLVE FIRE DEPARTMENT ISSUES

Comments: OK TO SET UP FOR BUSINESS