

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234296  
Address: 197 SW WINTER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Shawn Hoffman	Partial	Friday, April 12, 2024

Corrective Action Required:

1	Misc	Partial, - shell and skimmer bonded - bonding for power cover - bonding ring and all points attached - bonding wire running to pump location
---	------	--

OK to pour apron

**Comments:**