



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110702, Building Permit - Commercial
Address: 425 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, August 29, 2011

Corrective Action Required

1 MISC

OPEN ELECT JUNCTION BOX: 115

Corrective Action Required

2 MISC

UNUSED OPENING -- DOUBLE-SLAMMER WITH ONE HOLE
UNUSED: 148

Corrective Action Required

3 MISC

OPEN PULL BOX: 131

Partial Correction

4 MISC

CEILING FRAMING + ABOVE-CEILING SYSTEMS OK TO COVER
EXCEPT SPACES NOTED ABOVE

Comments: