

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240912

Address: 420 SW LONGVIEW BLVD, Unit:100, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Shawn Hoffman	Failed	Friday, April 12, 2024

Corrective Action Required:

1	Misc	- Fire caulk penetrations at fire walls
---	------	---

Comments: