

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230682
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Patrick Schonfeldt	Partial	Friday, April 12, 2024

Informational:	
1 Misc	4-9-24 PS Observed vac test of sanitary manholes, partial inspection
	SS 1-1 Passed
	SS 1-2 Passed
	SS 1-5 Passed
	4-12-24 PS Observed vac test of sanitary manhole
	SS1-3 Passed

Comments: