

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241061
Address: 2136 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Kyle Beard	Failed	Monday, April 15, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Part of basement ceiling has less than the required 6'8" clear ceiling height -electrical lines are exposed in the basement bathroom at the light fixture
---	--------------------------	---

Comments: